

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **Center of Applied Technology-North**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On December 5, 2018, **one hundred seventy-five (175)** lead water samples were collected from the **Center of Applied Technology-North**. Of these lead water samples, seven (7) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead result from the sample(s) collected at Center of Applied Technology-North were as follows:

Sample Number 000086-D-109 Masonry Locker Room Hand Sink-Left: 28.9 ppb (non-consumable).
Sample Number 000128-B-104 Practical Nursing Utility Room Hand Sink: 796 ppb (non-consumable).

Sample Number 000138-B-101 Network Tech Dual Sink Hand Sink-Left: 26 ppb (non-consumable).

Sample Number 000140-B-101 Network Tech Water Fountain: 38.1 ppb (consumable).

Sample Number 000148-B-105 Drafting Dual Sink-Left: 32.7 ppb (non-consumable).

Sample Number 000157-B-107 Graphic Arts Dual Sink-Right: 560 ppb (non-consumable).

Sample Number 000168-Media Work Room Hand Sink: 56.4 ppb (non-consumable).

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

1. One (1) consumable water source consisting of a water fountain will be shut off immediately and retested.
2. Six (6) non-consumable water sources consisting of hand sinks will be posted with green signage indicating "Hand Washing Only" and retested.

NEXT STEPS

1. Seven (7) consumable and non-consumable water sources will be replaced and retested in accordance with the regulations.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact Chris Williams, Environmental Issues Program Manager, at 410-360-0138. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

KCI Technologies
Tehsin Aurangabadwala
936 Ridgebrook Road
Sparks, MD 21152

Project Name: Center for Applied Technology
(9513)
Project / PO Number: N/A
Received: 12/05/2018
Reported: 01/14/2019

Analytical Testing Parameters

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (9513-1 Health Room Bathroom - (BR)- Left Hand Sink- (HS) BS NC, Drinking Water, 18L0443-01, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (3.1), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (12/27/18 1534), Analyzed (01/02/19 1210), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (9513-2 Wall Wash Station/ Eyewash (See Map) HS OT NC, Drinking Water, 18L0443-02, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (<1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (01/03/19 1205), Analyzed (01/08/19 1559), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (9513-3 Health Room BR- Right HS BS NC, Drinking Water, 18L0443-03, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (1.3), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (01/03/19 1205), Analyzed (01/08/19 1603), Analyst (GHW)

Table with 2 columns: Parameter (Client Sample ID, Sample Matrix, Lab Sample ID) and Value (9513-4 Office Men's BR HS BS NC, Drinking Water, 18L0443-04, etc.)

Metals, Total by EPA 200 Series Methods

Method: EPA 200.2/EPA 200.8

Table with 9 columns: Lead, Result (1.0), Limit(s) (20.0), RL (1.0), Units (ppb), Note, Prepared (01/03/19 1205), Analyzed (01/08/19 1604), Analyst (GHW)



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-5 Office Women's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:26
Lab Sample ID: 18L0443-05	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		01/03/19 1205	01/08/19 1605	GHW

Client Sample ID: 9513-6 Display Area- Women's BR HS- Left (L) BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:30
Lab Sample ID: 18L0443-06	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1607	GHW

Client Sample ID: 9513-7 Display Area- Women's BR HS-Left Center (LC) BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:30
Lab Sample ID: 18L0443-07	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		01/03/19 1205	01/08/19 1608	GHW

Client Sample ID: 9513-8 Display Area- Women's BR HS-Right Center (RC) BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:30
Lab Sample ID: 18L0443-08	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		01/03/19 1205	01/08/19 1613	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-9 Display Area- Women's BR HS- Right (R.) BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:30
Lab Sample ID: 18L0443-09	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1615	GHW

Client Sample ID: 9513-10 Display Area- Men's BR HS-L BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:32
Lab Sample ID: 18L0443-10	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.5	20.0	1.0	ppb		01/03/19 1205	01/08/19 1616	GHW

Client Sample ID: 9513-11 Display Area- Men's BR HS-LC BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:32
Lab Sample ID: 18L0443-11	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	4.5	20.0	1.0	ppb		01/03/19 1205	01/08/19 1617	GHW

Client Sample ID: 9513-12 Display Area- Men's BR HS-RC BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:32
Lab Sample ID: 18L0443-12	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	16.8	20.0	1.0	ppb		01/03/19 1205	01/08/19 1619	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-13 Display Area- Men's BR HS-R BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:32
Lab Sample ID: 18L0443-13	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1623	GHW

Client Sample ID: 9513-14 A-102 Diesel Mechanic Shop Locker Room HS-L BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:35
Lab Sample ID: 18L0443-14	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		01/03/19 1205	01/08/19 1624	GHW

Client Sample ID: 9513-15 A-102 Diesel Mechanic Shop Locker Room HS-R BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:35
Lab Sample ID: 18L0443-15	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.6	20.0	1.0	ppb		01/03/19 1205	01/08/19 1626	GHW

Client Sample ID: 9513-16 A-102 Diesel Mechanic Shop Water Fountain Bubbler- (B) DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:36
Lab Sample ID: 18L0443-16	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		01/03/19 1205	01/08/19 1631	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-17 A-102 Diesel Mechanic Shop Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:37
Lab Sample ID: 18L0443-17	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1632	GHW

Client Sample ID: 9513-18 A-102 Diesel Mechanic Shop Sink Sink-Center (C.) CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:37
Lab Sample ID: 18L0443-18	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		01/03/19 1205	01/08/19 1634	GHW

Client Sample ID: 9513-19 A-102 Diesel Mechanic Shop Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:37
Lab Sample ID: 18L0443-19	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1635	GHW

Client Sample ID: 9513-20 Faculty Women BR (By A-102 Diesel Mechanic Shop) HS-L BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:40
Lab Sample ID: 18L0443-20	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	9.1	20.0	1.0	ppb		01/03/19 1205	01/08/19 1636	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-21 Faculty Women BR (By A-102 Diesel Mechanic Shop) HS-R BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:40
Lab Sample ID: 18L0443-21	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	10.7	20.0	1.0	ppb		01/03/19 1205	01/08/19 1638	GHW

Client Sample ID: 9513-22 Faculty Men BR (By A-102 Diesel Mechanic Shop) HS-L BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:41
Lab Sample ID: 18L0443-22	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		01/03/19 1205	01/08/19 1642	GHW

Client Sample ID: 9513-23 Faculty Men BR (By A-102 Diesel Mechanic Shop) HS-R BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:41
Lab Sample ID: 18L0443-23	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.4	20.0	1.0	ppb		01/03/19 1205	01/08/19 1650	GHW

Client Sample ID: 9513-24 Motorcycle Repair Locker Room HS-L BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:45
Lab Sample ID: 18L0443-24	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	14.4	20.0	1.0	ppb		01/03/19 1205	01/08/19 1651	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-25 Motorcycle Repair Locker Room HS-R BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:45
Lab Sample ID: 18L0443-25	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		01/03/19 1205	01/08/19 1652	GHW

Client Sample ID: 9513-26 Dual Sink Outside (Motorcycle Repair Locker Rm) Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:46
Lab Sample ID: 18L0443-26	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	8.3	20.0	1.0	ppb		01/03/19 1205	01/08/19 1654	GHW

Client Sample ID: 9513-27 Dual Sink Outside (Motorcycle Repair Locker Rm) Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:46
Lab Sample ID: 18L0443-27	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	2.9	20.0	1.0	ppb		01/03/19 1205	01/08/19 1655	GHW

Client Sample ID: 9513-28 A-103-A Engine Lab Tri-Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:47
Lab Sample ID: 18L0443-28	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	6.9	20.0	1.0	ppb		01/03/19 1205	01/08/19 1656	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-29 A-103-A Engine Lab Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:47
Lab Sample ID: 18L0443-29	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.8	20.0	1.0	ppb		01/03/19 1205	01/08/19 1658	GHW

Client Sample ID: 9513-30 A-103-A Engine Lab Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:47
Lab Sample ID: 18L0443-30	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.4	20.0	1.0	ppb		01/03/19 1205	01/08/19 1659	GHW

Client Sample ID: 9513-32 A-105-B Engine Class Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:50
Lab Sample ID: 18L0443-32	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.5	20.0	1.0	ppb		01/03/19 1205	01/08/19 1700	GHW

Client Sample ID: 9513-33 A-105-B Engine Class Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:50
Lab Sample ID: 18L0443-33	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.1	20.0	1.0	ppb		01/03/19 1205	01/08/19 1706	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-34 A-114 Auto Collision Chop Tri-Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:53
Lab Sample ID: 18L0443-34	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	6.6	20.0	1.0	ppb		01/03/19 1205	01/08/19 1710	GHW

Client Sample ID: 9513-35 A-114 Auto Collision Chop Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:53
Lab Sample ID: 18L0443-35	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.5	20.0	1.0	ppb		01/03/19 1205	01/08/19 1711	GHW

Client Sample ID: 9513-36 A-114 Auto Collision Chop Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:53
Lab Sample ID: 18L0443-36	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	8.2	20.0	1.0	ppb		01/03/19 1205	01/08/19 1712	GHW

Client Sample ID: 9513-37 A-114 Auto Collision Chop Water Fountain Tri-Sink B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:53
Lab Sample ID: 18L0443-37	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1714	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-38 A-114 Auto Collision Shop Locker Room HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:59
Lab Sample ID: 18L0443-38	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.5	20.0	1.0	ppb		01/03/19 1205	01/08/19 1715	GHW

Client Sample ID: 9513-40 Collision Refinish Lab -BR HS-L BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:01
Lab Sample ID: 18L0443-40	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1716	GHW

Client Sample ID: 9513-41 Collision Refinish Lab -BR HS-R BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:01
Lab Sample ID: 18L0443-41	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	12.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1718	GHW

Client Sample ID: 9513-42 Water Fountain (by A-112-B) DF DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:03
Lab Sample ID: 18L0443-42	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	6.6	20.0	1.0	ppb		01/03/19 1205	01/08/19 1723	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-43 Tri-Sink (by 112-A) Sink-L OT NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:04
Lab Sample ID: 18L0443-43	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1724	GHW

Client Sample ID: 9513-44 Tri-Sink (by 112-A) Sink-C OT NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:04
Lab Sample ID: 18L0443-44	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	5.3	20.0	1.0	ppb		01/03/19 1205	01/08/19 1728	GHW

Client Sample ID: 9513-45 Tri-Sink (by 112-A) Sink-R OT NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:04
Lab Sample ID: 18L0443-45	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	9.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1733	GHW

Client Sample ID: 9513-46 Tri-Sink (by 110-A) Sink-L OT NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:05
Lab Sample ID: 18L0443-46	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.6	20.0	1.0	ppb		01/03/19 1205	01/08/19 1734	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-47 Tri-Sink (by 110-A) Sink-C OT NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:05
Lab Sample ID: 18L0443-47	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.6	20.0	1.0	ppb		01/03/19 1205	01/08/19 1735	GHW

Client Sample ID: 9513-48 Tri-Sink (by 110-A) Sink-R OT NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:05
Lab Sample ID: 18L0443-48	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.9	20.0	1.0	ppb		01/03/19 1205	01/08/19 1741	GHW

Client Sample ID: 9513-49 Tri-Sink (108-A) Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:06
Lab Sample ID: 18L0443-49	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1742	GHW

Client Sample ID: 9513-50 Tri-Sink (108-A) Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:06
Lab Sample ID: 18L0443-50	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1743	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-51 Tri-Sink (108-A) Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:11
Lab Sample ID: 18L0443-51	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.3	20.0	1.0	ppb		01/03/19 1205	01/08/19 1745	GHW

Client Sample ID: 9513-55 C-104 Office BR HS-L BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:14
Lab Sample ID: 18L0443-55	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1746	GHW

Client Sample ID: 9513-56 C-104 Office BR HS-R BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:14
Lab Sample ID: 18L0443-56	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1747	GHW

Client Sample ID: 9513-57 Hall Fountain (see map) DF DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:15
Lab Sample ID: 18L0443-57	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1749	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-58 Food Service Kitchen Locker Room HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:06
Lab Sample ID: 18L0443-58	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1753	GHW

Client Sample ID: 9513-59 Kitchen Dual Sink (by Hood Fan) -Left Sink-L KS C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:08
Lab Sample ID: 18L0443-59	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		01/03/19 1205	01/08/19 1758	GHW

Client Sample ID: 9513-60 Kitchen Dual Sink (by Hood Fan) -Right Sink-R KS C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:08
Lab Sample ID: 18L0443-60	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1800	GHW

Client Sample ID: 9513-61 Kitchen (by Hood Fan) -Left HS KS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:08
Lab Sample ID: 18L0443-61	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1801	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-62 Kitchen (by Loading Dock) HS KS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:10
Lab Sample ID: 18L0443-62	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.4	20.0	1.0	ppb		01/03/19 1205	01/08/19 1802	GHW

Client Sample ID: 9513-63 Kitchen Men's Locker Room HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:11
Lab Sample ID: 18L0443-63	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1804	GHW

Client Sample ID: 9513-64 Kitchen (by Hood Fan)-Right HS KS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:11
Lab Sample ID: 18L0443-64	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1805	GHW

Client Sample ID: 9513-65 Kitchen Dual Sink (by Hood Fan)-Right Sink-L KS C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:12
Lab Sample ID: 18L0443-65	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1205	01/08/19 1806	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-66 Kitchen Dual Sink (by Hood Fan)-Right Sink-R KS C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:12
Lab Sample ID: 18L0443-66	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		01/03/19 1205	01/08/19 1808	GHW

Client Sample ID: 9513-67 Kitchen Storage Room HS KS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:14
Lab Sample ID: 18L0443-67	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1728	GHW

Client Sample ID: 9513-68 Kitchen Water Fountain (by Mixer & Freezer) DF DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:14
Lab Sample ID: 18L0443-68	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1732	GHW

Client Sample ID: 9513-69 Dish Washer Room HS KS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:15
Lab Sample ID: 18L0443-69	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1736	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-70 Dish Washer Room Sprayer OT C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:15
Lab Sample ID: 18L0443-70	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.1	20.0	1.0	ppb		01/03/19 1236	01/09/19 1737	GHW

Client Sample ID: 9513-71 Cafe Sink (by Office) HS-L KS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:19
Lab Sample ID: 18L0443-71	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		01/03/19 1236	01/09/19 1738	GHW

Client Sample ID: 9513-72 Cafe Sink (by Office) HS-LC KS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:19
Lab Sample ID: 18L0443-72	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	4.2	20.0	1.0	ppb		01/03/19 1236	01/09/19 1740	GHW

Client Sample ID: 9513-73 Cafe Sink (by Office) HS-RC KS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:19
Lab Sample ID: 18L0443-73	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1741	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-74 Cafe Sink (by Office) HS-R KS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:19
Lab Sample ID: 18L0443-74	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1742	GHW

Client Sample ID: 9513-75 Cafe Water Fountain DF DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:20
Lab Sample ID: 18L0443-75	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1744	GHW

Client Sample ID: 9513-76 Construction D- 105 Electricity Locker Room HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:18
Lab Sample ID: 18L0443-76	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		01/03/19 1236	01/09/19 1745	GHW

Client Sample ID: 9513-77 D-105 Electric Fountain DF DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:19
Lab Sample ID: 18L0443-77	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	5.5	20.0	1.0	ppb		01/03/19 1236	01/09/19 1746	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-78 D-105 Electric Tri-Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:19
Lab Sample ID: 18L0443-78	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		01/03/19 1236	01/09/19 1753	GHW

Client Sample ID: 9513-79 D-105 Electric Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:19
Lab Sample ID: 18L0443-79	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	8.2	20.0	1.0	ppb		01/03/19 1236	01/09/19 1755	GHW

Client Sample ID: 9513-80 D-105 Electric Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:19
Lab Sample ID: 18L0443-80	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	16.7	20.0	1.0	ppb		01/03/19 1236	01/09/19 1756	GHW

Client Sample ID: 9513-81 Carpentry- 107 BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:21
Lab Sample ID: 18L0443-81	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	2.2	20.0	1.0	ppb		01/03/19 1236	01/09/19 1757	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-82 Carpentry- 107 Tri-Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:23
Lab Sample ID: 18L0443-82	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	2.5	20.0	1.0	ppb		01/03/19 1236	01/09/19 1759	GHW

Client Sample ID: 9513-83 Carpentry- 107 Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:23
Lab Sample ID: 18L0443-83	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		01/03/19 1236	01/09/19 1800	GHW

Client Sample ID: 9513-84 Carpentry- 107 Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:23
Lab Sample ID: 18L0443-84	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1801	GHW

Client Sample ID: 9513-85 Carpentry- 107 Water Fountain B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:23
Lab Sample ID: 18L0443-85	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	2.7	20.0	1.0	ppb		01/03/19 1236	01/09/19 1803	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID:	9513-86 D-109 Masonry Locker Room HS-L BS NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 6:24
Lab Sample ID:	18L0443-86		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	28.9	20.0	1.0	ppb		01/03/19 1236	01/09/19 1804	GHW

Client Sample ID:	9513-87 D-109 Masonry Locker Room HS-R BS NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 6:24
Lab Sample ID:	18L0443-87		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	5.9	20.0	1.0	ppb		01/03/19 1236	01/09/19 1811	GHW

Client Sample ID:	9513-88 D-109 Masonry Water Fountain B DF C	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 6:26
Lab Sample ID:	18L0443-88		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		01/03/19 1236	01/09/19 1815	GHW

Client Sample ID:	9513-89 D-109 Masonry Tri-Sink Sink-L CR NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 6:26
Lab Sample ID:	18L0443-89		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1816	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-90 D-109 Masonry Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:26
Lab Sample ID: 18L0443-90	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	6.6	20.0	1.0	ppb		01/03/19 1236	01/09/19 1818	GHW

Client Sample ID: 9513-91 D-109 Masonry Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:26
Lab Sample ID: 18L0443-91	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	2.7	20.0	1.0	ppb		01/03/19 1236	01/09/19 1819	GHW

Client Sample ID: 9513-92 110 - Nurse Lab Locker Room HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:28
Lab Sample ID: 18L0443-92	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.3	20.0	1.0	ppb		01/03/19 1236	01/09/19 1820	GHW

Client Sample ID: 9513-93 110-Nurse Lab Water Fountain B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:30
Lab Sample ID: 18L0443-93	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	2.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1824	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-94 110-Nurse Lab Tri-Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:30
Lab Sample ID: 18L0443-94	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	9.3	20.0	1.0	ppb		01/03/19 1236	01/09/19 1826	GHW

Client Sample ID: 9513-95 110-Nurse Lab Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:30
Lab Sample ID: 18L0443-95	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.9	20.0	1.0	ppb		01/03/19 1236	01/09/19 1827	GHW

Client Sample ID: 9513-96 110-Nurse Lab Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:30
Lab Sample ID: 18L0443-96	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	7.6	20.0	1.0	ppb		01/03/19 1236	01/09/19 1829	GHW

Client Sample ID: 9513-97 D-108-Plumbing Dual Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:31
Lab Sample ID: 18L0443-97	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.1	20.0	1.0	ppb		01/03/19 1236	01/09/19 1830	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-98 D-108-Plumbing Dual Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:32
Lab Sample ID: 18L0443-98	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.1	20.0	1.0	ppb		01/03/19 1236	01/09/19 1834	GHW

Client Sample ID: 9513-99 D-108-Plumbing Water Fountain B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:33
Lab Sample ID: 18L0443-99	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1835	GHW

Client Sample ID: 9513-100 D-108-Plumbing Locker Room HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:33
Lab Sample ID: 18L0443-AA	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		01/03/19 1236	01/09/19 1837	GHW

Client Sample ID: 9513-101 D-106-HVAC Locker Room HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:35
Lab Sample ID: 18L0443-AB	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1841	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-102 D-106-HVAC Water Fountain B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:35
Lab Sample ID: 18L0443-AC	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1842	GHW

Client Sample ID: 9513-103 D-106-HVAC Dual Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:35
Lab Sample ID: 18L0443-AD	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1844	GHW

Client Sample ID: 9513-104 D-106-HVAC Dual Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:35
Lab Sample ID: 18L0443-AE	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		01/03/19 1236	01/09/19 1845	GHW

Client Sample ID: 9513-105 D104 Building Maintenance Tri-Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:37
Lab Sample ID: 18L0443-AF	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	6.7	20.0	1.0	ppb		01/03/19 1236	01/09/19 1846	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-106 D104 Building Maintenance Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:39
Lab Sample ID: 18L0443-AG	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1848	GHW

Client Sample ID: 9513-107 D104 Building Maintenance Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:39
Lab Sample ID: 18L0443-AH	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		01/03/19 1236	01/09/19 1852	GHW

Client Sample ID: 9513-108 D104 Building Maintenance Water Fountain B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:39
Lab Sample ID: 18L0443-AI	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1859	GHW

Client Sample ID: 9513-109 D104 Building Maintenance Locker Rm HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:40
Lab Sample ID: 18L0443-AJ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	2.9	20.0	1.0	ppb		01/03/19 1236	01/09/19 1900	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID:	9513-110 Women's Locker Room (Lobby) HS-L BS NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 6:40
Lab Sample ID:	18L0443-AK		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		01/03/19 1236	01/09/19 1901	GHW

Client Sample ID:	9513-111 Women's Locker Room (Lobby) HS-R BS NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 6:40
Lab Sample ID:	18L0443-AL		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1903	GHW

Client Sample ID:	9513-112 Men's Locker Rom (Lobby) HS-L BS NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 6:41
Lab Sample ID:	18L0443-AM		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1904	GHW

Client Sample ID:	9513-113 Men's Locker Rom (Lobby) HS-R BS NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 6:41
Lab Sample ID:	18L0443-AN		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.5	20.0	1.0	ppb		01/03/19 1236	01/09/19 1905	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-114 Welding Tri-Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:42
Lab Sample ID: 18L0443-AO	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.5	20.0	1.0	ppb		01/03/19 1236	01/09/19 1907	GHW

Client Sample ID: 9513-115 Welding Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:43
Lab Sample ID: 18L0443-AP	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1908	GHW

Client Sample ID: 9513-116 Welding Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:43
Lab Sample ID: 18L0443-AQ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.6	20.0	1.0	ppb		01/03/19 1236	01/09/19 1910	GHW

Client Sample ID: 9513-117 Welding Water Fountain B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:44
Lab Sample ID: 18L0443-AR	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1914	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-118 Welding Locker Room HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:44
Lab Sample ID: 18L0443-AS	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1918	GHW

Client Sample ID: 9513-119 Upstairs Classroom BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:47
Lab Sample ID: 18L0443-AT	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		01/03/19 1236	01/09/19 1919	GHW

Client Sample ID: 9513-121 Upstairs Classroom HS CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:47
Lab Sample ID: 18L0443-AV	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	6.1	20.0	1.0	ppb		01/03/19 1236	01/09/19 1921	GHW

Client Sample ID: 9513-122 D101A Machine Shop Tri-Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:49
Lab Sample ID: 18L0443-AW	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1922	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-123 D101A Machine Shop Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:49
Lab Sample ID: 18L0443-AX	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1923	GHW

Client Sample ID: 9513-124 D101A Machine Shop Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:49
Lab Sample ID: 18L0443-AY	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		01/03/19 1236	01/09/19 1925	GHW

Client Sample ID: 9513-125 D101A Machine Shop Water Fountain B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:49
Lab Sample ID: 18L0443-AZ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1926	GHW

Client Sample ID: 9513-126 D101A Machine Shop Locker Room HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:50
Lab Sample ID: 18L0443-BA	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1930	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-127 Water Fountain (By Elect. Room) Drinking Fountain (DF) DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:50
Lab Sample ID: 18L0443-BB	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1236	01/09/19 1931	GHW

Client Sample ID: 9513-128 B-104 Practical Nursing Utility Room HS CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:54
Lab Sample ID: 18L0443-BC	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	796	20.0	1.0	ppb		12/27/18 1534	01/02/19 1214	GHW

Client Sample ID: 9513-131 B-104 Tri-Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:56
Lab Sample ID: 18L0443-BF	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.5	20.0	1.0	ppb		01/03/19 1247	01/10/19 1353	GHW

Client Sample ID: 9513-132 B-104 Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:56
Lab Sample ID: 18L0443-BG	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.1	20.0	1.0	ppb		01/03/19 1247	01/10/19 1357	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-133 B-104 Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:56
Lab Sample ID: 18L0443-BH	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.1	20.0	1.0	ppb		01/03/19 1247	01/10/19 1359	GHW

Client Sample ID: 9513-134 B-104 BR-Left HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:57
Lab Sample ID: 18L0443-BI	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.5	20.0	1.0	ppb		01/03/19 1247	01/10/19 1400	GHW

Client Sample ID: 9513-135 B-104 BR-Right HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:57
Lab Sample ID: 18L0443-BJ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1401	GHW

Client Sample ID: 9513-136 B-102 Graphic Design Men's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:58
Lab Sample ID: 18L0443-BK	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.5	20.0	1.0	ppb		01/03/19 1247	01/10/19 1403	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID:	9513-137 B-102 Graphic Design Women's BR HS BS NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 6:59
Lab Sample ID:	18L0443-BL		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1408	GHW

Client Sample ID:	9513-138 B-101 Network Tech. Dual Sink HS-L CR NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 6:59
Lab Sample ID:	18L0443-BM		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	26.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1409	GHW

Client Sample ID:	9513-139 B-101 Network Tech. Dual Sink HS-R CR NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 7:01
Lab Sample ID:	18L0443-BN		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	5.8	20.0	1.0	ppb		01/03/19 1247	01/10/19 1411	GHW

Client Sample ID:	9513-140 B-101 Network Tech. Water Fountain B DF C	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 7:01
Lab Sample ID:	18L0443-BO		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	38.1	20.0	1.0	ppb		01/03/19 1247	01/10/19 1412	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-141 B-101 Network Tech. Men's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:02
Lab Sample ID: 18L0443-BP	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	5.8	20.0	1.0	ppb		01/03/19 1247	01/10/19 1413	GHW

Client Sample ID: 9513-142 B-101 Network Tech. Women's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:02
Lab Sample ID: 18L0443-BQ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.2	20.0	1.0	ppb		01/03/19 1247	01/10/19 1417	GHW

Client Sample ID: 9513-143 B-103 Computer Network Tech. Women's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:05
Lab Sample ID: 18L0443-BR	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.7	20.0	1.0	ppb		01/03/19 1247	01/10/19 1419	GHW

Client Sample ID: 9513-144 B-103 Computer Network Tech. Men's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:05
Lab Sample ID: 18L0443-BS	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	2.8	20.0	1.0	ppb		01/03/19 1247	01/10/19 1420	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID:	9513-145 B-103 Computer Network Tech. Water Fountain B DF C	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 7:05
Lab Sample ID:	18L0443-BT		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.3	20.0	1.0	ppb		01/03/19 1247	01/10/19 1425	GHW

Client Sample ID:	9513-146 B-103 Computer Network Tech. Dual Sink Sink-L CR NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 7:06
Lab Sample ID:	18L0443-BU		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	5.7	20.0	1.0	ppb		01/03/19 1247	01/10/19 1427	GHW

Client Sample ID:	9513-147 B-103 Computer Network Tech. Dual Sink Sink-R CR NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 7:06
Lab Sample ID:	18L0443-BV		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	6.7	20.0	1.0	ppb		01/03/19 1247	01/10/19 1428	GHW

Client Sample ID:	9513-148 B-105 Drafting Dual Sink Sink-L CR NC	Collected By:	Bridget Lamborn
Sample Matrix:	Drinking Water	Collection Date:	12/05/2018 7:08
Lab Sample ID:	18L0443-BW		

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	32.7	20.0	1.0	ppb		01/03/19 1247	01/10/19 1430	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-149 B-105 Drafting Dual Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:08
Lab Sample ID: 18L0443-BX	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1431	GHW

Client Sample ID: 9513-150 B-105 Drafting Water Fountain B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:09
Lab Sample ID: 18L0443-BY	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	2.1	20.0	1.0	ppb		01/03/19 1247	01/10/19 1432	GHW

Client Sample ID: 9513-151 B-105 Drafting Men's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:14
Lab Sample ID: 18L0443-BZ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	7.3	20.0	1.0	ppb		01/03/19 1247	01/10/19 1436	GHW

Client Sample ID: 9513-152 B-105 Drafting Dual Women's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:14
Lab Sample ID: 18L0443-CA	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	2.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1444	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-153 B-107 Graphic Arts Women's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:16
Lab Sample ID: 18L0443-CB	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1446	GHW

Client Sample ID: 9513-154 B-107 Graphic Arts Men's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:16
Lab Sample ID: 18L0443-CC	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.6	20.0	1.0	ppb		01/03/19 1247	01/10/19 1447	GHW

Client Sample ID: 9513-155 B-107 Graphic Arts Water Fountain B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:17
Lab Sample ID: 18L0443-CD	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.2	20.0	1.0	ppb		01/03/19 1247	01/10/19 1448	GHW

Client Sample ID: 9513-156 B-107 Graphic Arts Dual Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:17
Lab Sample ID: 18L0443-CE	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.9	20.0	1.0	ppb		01/03/19 1247	01/10/19 1450	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-157 B-107 Graphic Arts Dual Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:17
Lab Sample ID: 18L0443-CF	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	560	20.0	1.0	ppb		01/03/19 1247	01/10/19 1451	GHW

Client Sample ID: 9513-163 B-109 Cosmetology BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:22
Lab Sample ID: 18L0443-CL	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	3.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1452	GHW

Client Sample ID: 9513-164 B-109 Cosmetology Women Dressing Rm HS-L OT NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:22
Lab Sample ID: 18L0443-CM	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		01/03/19 1247	01/10/19 1454	GHW

Client Sample ID: 9513-165 B-109 Cosmetology Women Dressing Rm HS-R OT NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:22
Lab Sample ID: 18L0443-CN	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.1	20.0	1.0	ppb		01/03/19 1247	01/10/19 1455	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-167 Counseling Office BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:23
Lab Sample ID: 18L0443-CP	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1500	GHW

Client Sample ID: 9513-168 Media Work Room HS OT NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:25
Lab Sample ID: 18L0443-CQ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	56.4	20.0	1.0	ppb		12/27/18 1534	01/02/19 1216	GHW

Client Sample ID: 9513-169 Hall Fountain (by Faculty Room) DF DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:27
Lab Sample ID: 18L0443-CR	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	4.2	20.0	1.0	ppb		01/03/19 1247	01/10/19 1505	GHW

Client Sample ID: 9513-170 Faculty Men's BR (By B-168 Lounge) HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:28
Lab Sample ID: 18L0443-CS	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1506	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-171 Faculty Women's BR (By B-168 Lounge) HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:29
Lab Sample ID: 18L0443-CT	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.9	20.0	1.0	ppb		01/03/19 1247	01/10/19 1507	GHW

Client Sample ID: 9513-172 Hall Fountain (By B-168 Lounge) DF DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:31
Lab Sample ID: 18L0443-CU	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	5.8	20.0	1.0	ppb		01/03/19 1247	01/10/19 1509	GHW

Client Sample ID: 9513-173 Green House Women's BR HS-L BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:43
Lab Sample ID: 18L0443-CV	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1510	GHW

Client Sample ID: 9513-174 Green House Women's BR HS-R BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:43
Lab Sample ID: 18L0443-CW	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.4	20.0	1.0	ppb		01/03/19 1247	01/10/19 1511	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-175 Green House Men's Locker Room BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:44
Lab Sample ID: 18L0443-CX	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	14.8	20.0	1.0	ppb		01/03/19 1247	01/10/19 1513	GHW

Client Sample ID: 9513-176 E104-Tri-Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:44
Lab Sample ID: 18L0443-CY	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	1.3	20.0	1.0	ppb		01/03/19 1247	01/10/19 1518	GHW

Client Sample ID: 9513-177 E104-Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:45
Lab Sample ID: 18L0443-CZ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1519	GHW

Client Sample ID: 9513-178 E104-Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:45
Lab Sample ID: 18L0443-DA	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
---	--------	----------	----	-------	------	----------	----------	---------

Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1524	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-179 E104-Water Fountain B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:45
Lab Sample ID: 18L0443-DB	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.2	20.0	1.0	ppb		01/03/19 1247	01/10/19 1528	GHW

Client Sample ID: 9513-180 E102-Equipment Maintenance Water Fountain B DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:47
Lab Sample ID: 18L0443-DC	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1529	GHW

Client Sample ID: 9513-181 E102-Equipment Maintenance Tri-Sink Sink-L CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:47
Lab Sample ID: 18L0443-DD	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	18.2	20.0	1.0	ppb		01/03/19 1247	01/10/19 1530	GHW

Client Sample ID: 9513-182 E102-Equipment Maintenance Tri-Sink Sink-C CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:47
Lab Sample ID: 18L0443-DE	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	2.3	20.0	1.0	ppb		01/03/19 1247	01/10/19 1536	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-183 E102-Equipment Maintenance Tri-Sink Sink-R CR NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:47
Lab Sample ID: 18L0443-DF	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	11.9	20.0	1.0	ppb		01/03/19 1247	01/10/19 1537	GHW

Client Sample ID: 9513-184 Training Facilities Men's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:49
Lab Sample ID: 18L0443-DG	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.8	20.0	1.0	ppb		01/03/19 1247	01/10/19 1538	GHW

Client Sample ID: 9513-185 Training Facilities Women's BR HS BS NC	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 7:49
Lab Sample ID: 18L0443-DH	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	<1.0	20.0	1.0	ppb		01/03/19 1247	01/10/19 1540	GHW

Client Sample ID: 9513-186 Diesel Mechanic Shop Water Fountain Between Bathrooms DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 5:43
Lab Sample ID: 18L0443-DI	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	3.4	20.0	1.0	ppb		01/03/19 1247	01/10/19 1541	GHW



Microbac Laboratories, Inc. - Baltimore

CERTIFICATE OF ANALYSIS

18L0443

Client Sample ID: 9513-187 Hallway Near Graphic Arts Water Fountain DF C	Collected By: Bridget Lamborn
Sample Matrix: Drinking Water	Collection Date: 12/05/2018 6:28
Lab Sample ID: 18L0443-DJ	

Metals, Total by EPA 200 Series Methods	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.2/EPA 200.8								
Lead	1.7	20.0	1.0	ppb		01/03/19 1247	01/10/19 1543	GHW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Jake Mason
 Client Relations
 Reported: 01/14/2019 12:08



18L0443

KCI Technologies, Inc. Chain of Cu

KCI Technologies, Inc. 936 Ridgebrook Rd., Baltimore, MD 21152 (410) 316-

AACPS Drinking Water Lead SurveySample Date/Start Time: 12.5.18 0500 End Time 0756Bottle Type/Preservative: 250 ml plastic/HNO3 Analysis: (EPA 200.8) Samples Preserved: Yes or No Notes:Sampled/Relinquished by B LAMBORN Received at Microbac by Edgar Maly Date/Time 12.5.18 8:40Total Samples Submitted 173 Total Samples Not Submitted 14**Center of Applied Technology North CATN (9513)****800 Stevenson Rd., Severn, MD 21144****ALL OUTLETS WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM**

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bib, etc.)	Outlet Key Codes	Consumption C or NC	Sample Time
1	Health Room Bathroom - (BR)- Left	Hand Sink- (HS)	BS	NC	0525
2	Wall Wash Station/ Eyewash (See Map)	HS	OT	NC	0525
3	Health Room BR- Right	HS	BS	NC	0525
4	Office Men's BR	HS	BS	NC	0526
5	Office Women's BR	HS	BS	NC	0526
6	Display Area- Women's BR	HS- Left (L)	BS	NC	0530
7	Display Area- Women's BR	HS-Left Center (LC)	BS	NC	0530
8	Display Area- Women's BR	HS-Right Center (RC)	BS	NC	0530
9	Display Area- Women's BR	HS- Right (R.)	BS	NC	0530
10	Display Area- Men's BR	HS-L	BS	NC	0532
11	Display Area- Men's BR	HS-LC	BS	NC	0532
12	Display Area- Men's BR	HS-RC	BS	NC	0532
13	Display Area- Men's BR	HS-R	BS	NC	0532
14	A-102 Diesel Mechanic Shop Locker Room	HS-L	BS	NC	0535
15	A-102 Diesel Mechanic Shop Locker Room	HS-R	BS	NC	0535
16	A-102 Diesel Mechanic Shop Water Fountain	Bubbler- (B)	DF	C	0536
17	A-102 Diesel Mechanic Shop Sink	Sink-L	CR	NC	0537
18	A-102 Diesel Mechanic Shop Sink	Sink-Center (C.)	CR	NC	0537



KCI Technologies, Inc. Chain of Custody

KCI Technologies, Inc. 936 Ridgebrook Rd., Baltimore, MD 21152 (410) 316-7800 John.Adams@kci.com

AACPS Drinking Water Lead Survey

Center of Applied Technology North CATN (9513)

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bib, etc.)	Outlet Key Codes	Consumption C or NC	Sample Time
19	A-102 Diesel Mechanic Shop Sink	Sink-R	CR	NC	0537
20	Faculty Women's BR (By A-102 Diesel Mechanic Shop)	HS-L	BS	NC	0540
21	Faculty Women's BR (By A-102 Diesel Mechanic Shop)	HS-R	BS	NC	0540
22	Faculty Men's BR (By A-102 Diesel Mechanic Shop)	HS-L	BS	NC	0541
23	Faculty Men's BR (By A-102 Diesel Mechanic Shop)	HS-R	BS	NC	0541
24	Motorcycle Repair Locker Room	HS-L	BS	NC	0545
25	Motorcycle Repair Locker Room	HS-R <i>HOT WATER ONLY</i>	BS	NC	0545
26	Dual Sink Outside (Motorcycle Repair Locker Room)	Sink-L	CR	NC	0546
27	Dual Sink Outside (Motorcycle Repair Locker Room)	Sink-R	CR	NC	0546
28	A-103-A Engine Lab Tri-Sink	Sink-L	CR	NC	0547
29	A-103-A Engine Lab Tri-Sink	Sink-C	CR	NC	0547
30	A-103-A Engine Lab Tri-Sink	Sink-R	CR	NC	0547
31	A-105-B Engine Class Tri-Sink	Sink-L	CR	NC	<i>NOT WORKING</i>
32	A-105-B Engine Class Tri-Sink	Sink-C	CR	NC	0550
33	A-105-B Engine Class Tri-Sink	Sink-R	CR	NC	0550
34	A-114 Auto Collision Chop Tri-Sink	Sink-L	CR	NC	0553
35	A-114 Auto Collision Chop Tri-Sink	Sink-C	CR	NC	0553
36	A-114 Auto Collision Chop Tri-Sink	Sink-R	CR	NC	0553
37	A-114 Auto Collision Chop Water Fountain Tri-Sink	B	DF	C	0553
38	A-114 Auto Collision Shop Locker Room	HS	BS	NC	0559
39	Collision Refinish Lab	Slop Sink (Do Not Sample)	OT	NC	—



KCI Technologies, Inc. Chain of Custody

KCI Technologies, Inc. 936 Ridgebrook Rd., Baltimore, MD 21152 (410) 316-7800 John.Adams@kci.com

AACPS Drinking Water Lead Survey

Center of Applied Technology North CATN (9513)

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bib, etc.)	Outlet Key Codes	Consumption C or NC	Sample Time
40	Collision Refinish Lab -BR	HS-L	BS	NC	0601
41	Collision Refinish Lab -BR	HS-R	BS	NC	0601
42	Water Fountain (by A-112-B)	DF	DF	C	0603
43	Tri-Sink (by 112-A)	Sink-L	OT	NC	0604 HOT TAP
44	Tri-Sink (by 112-A)	Sink-C	OT	NC	0604
45	Tri-Sink (by 112-A)	Sink-R	OT	NC	0604
46	Tri-Sink (by 110-A)	Sink-L	OT	NC	0605
47	Tri-Sink (by 110-A)	Sink-C	OT	NC	0605
48	Tri-Sink (by 110-A)	Sink-R	OT	NC	0605 DRIP
49	Tri-Sink (108-A)	Sink-L	CR	NC	0606
50	Tri-Sink (108-A)	Sink-C	CR	NC	0606
51	Tri-Sink (108-A)	Sink-R	CR	NC	0611
52	C-105 Cosmetology	Sprayer-L (Do Not Sample)	OT	NC	-
53	C-105 Cosmetology	Sprayer-C (Do Not Sample)	OT	NC	-
54	C-105 Cosmetology	Sprayer-R (Do Not Sample)	OT	NC	-
55	C-104 Office BR	HS-L	BS	NC	0614
56	C-104 Office BR	HS-R	BS	NC	0614
57	Hall Fountain (see map)	DF	DF	C	0615
58	Food Service Kitchen Locker Room	HS	BS	NC	0506
59	Kitchen Dual Sink (by Hood Fan) -Left	Sink-L	KS	C	0508
60	Kitchen Dual Sink (by Hood Fan) Left Right	Sink-R	KS	C	0508
61	Kitchen (by Hood Fan) -Left	HS	KS	NC	0508
62	Kitchen (by Loading Dock)	HS	KS	NC	0510
63	Kitchen Men's Locker Room	HS	BS	NC	0511
64	Kitchen (by Hood Fan)-Right	HS	KS	NC	0511
65	Kitchen Dual Sink (by Hood Fan)-Right	Sink-L	KS	C	0512



KCI Technologies, Inc. Chain of Custody

KCI Technologies, Inc. 936 Ridgebrook Rd., Baltimore, MD 21152 (410) 316-7800 John.Adams@kci.com

AACPS Drinking Water Lead Survey

Center of Applied Technology North CATN (9513)

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bib, etc.)	Outlet Key Codes	Consumption C or NC	Sample Time
66	Kitchen Dual Sink (by Hood Fan)-Right	Sink-R	KS	C	0512 DRIPPING
67	Kitchen Storage Room	HS	KS	NC	0514
68	Kitchen Water Fountain (by Mixer & Freezer)	DF	DF	C	0514
69	Dish Washer Room	HS	KS	NC	0515
70	Dish Washer Room	Sprayer	OT	C	0515
71	Café Sink (by Office)	HS-L	KS	NC	0519
72	Café Sink (by Office)	HS-LC	KS	NC	0519
73	Café Sink (by Office)	HS-RC	KS	NC	0519
74	Café Sink (by Office)	HS-R	KS	NC	0519
75	Café Water Fountain	DF	DF	C	0520
76	Construction D- 105 Electricity Locker Room	HS	BS	NC	0618
77	D-105 Electric Fountain	DF	DF	C	0619
78	D-105 Electric Tri-Sink	Sink-L	CR	NC	0619 DRIPPING
79	D-105 Electric Tri-Sink	Sink-C	CR	NC	0619
80	D-105 Electric Tri-Sink	Sink-R	CR	NC	0619
81	Carpentry- 107 BR	HS	BS	NC	0621 HOT ONLY
82	Carpentry- 107 Tri-Sink	Sink-L	CR	NC	0623
83	Carpentry- 107 Tri-Sink	Sink-C	CR	NC	0623
84	Carpentry- 107 Tri-Sink	Sink-R	CR	NC	0623
85	Carpentry- 107 Water Fountain	B	DF	C	0623
86	D-109 Masonry Locker Room	HS-L	BS	NC	0624
87	D-109 Masonry Locker Room	HS-R	BS	NC	0624
88	D-109 Masonry Water Fountain	B	DF	C	0626
89	D-109 Masonry Tri-Sink	Sink-L	CR	NC	0626 DRIPPING
90	D-109 Masonry Tri-Sink	Sink-C	CR	NC	0626 HOT ONLY



KCI Technologies, Inc. Chain of Custody

KCI Technologies, Inc. 936 Ridgebrook Rd., Baltimore, MD 21152 (410) 316-7800 John.Adams@kci.com

AACPS Drinking Water Lead Survey

Center of Applied Technology North CATN (9513)

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bib, etc.)	Outlet Key Codes	Consumption C or NC	Sample Time
91	D-109 Masonry Tri-Sink	Sink-R	CR	NC	0626
92	110 - Nurse Lab Locker Room	HS	BS	NC	0628
93	110-Nurse Lab Water Fountain	B	DF	C	0630
94	110-Nurse Lab Tri-Sink	Sink-L	CR	NC	0630
95	110-Nurse Lab Tri-Sink	Sink-C	CR	NC	0630
96	110-Nurse Lab Tri-Sink	Sink-R	CR	NC	0630
97	D-108-Plumbing Dual Sink	Sink-L	CR	NC	0631
98	D-108-Plumbing Dual Sink	Sink-R	CR	NC	0632 <i>not only</i>
99	D-108-Plumbing Water Fountain	B	DF	C	0633
100	D-108-Plumbing Locker Room	HS	BS	NC	0633
101	D-106-HVAC Locker Room	HS	BS	NC	0635
102	D-106-HVAC Water Fountain	B	DF	C	0635
103	D-106-HVAC Dual Sink	Sink-L	CR	NC	0635
104	D-106-HVAC Dual Sink	Sink-R	CR	NC	0635
105	D104 Building Maintenance Tri-Sink	Sink-L	CR	NC	0637
106	D104 Building Maintenance Tri-Sink	Sink-C	CR	NC	0639
107	D104 Building Maintenance Tri-Sink	Sink-R	CR	NC	0639
108	D104 Building Maintenance Water Fountain	B	DF	C	0639
109	D104 Building Maintenance Locker Room	HS	BS	NC	0640
110	Women's Locker Room (Lobby)	HS-L	BS	NC	0640
111	Women's Locker Room (Lobby)	HS-R	BS	NC	0640
112	Men's Locker Rom (Lobby)	HS-L	BS	NC	0641
113	Men's Locker Rom (Lobby)	HS-R	BS	NC	0641
114	Welding Tri-Sink	Sink-L	CR	NC	0642



KCI Technologies, Inc. Chain of Custody

KCI Technologies, Inc. 936 Ridgebrook Rd., Baltimore, MD 21152 (410) 316-7800 John.Adams@kci.com

AACPS Drinking Water Lead Survey

Center of Applied Technology North CATN (9513)

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bib, etc.)	Outlet Key Codes	Consumption C or NC	Sample Time
115	Welding Tri-Sink	Sink-C	CR	NC	0643
116	Welding Tri-Sink	Sink-R	CR	NC	0643
117	Welding Water Fountain	B	DF	C	0644
118	Welding Locker Room	HS	BS	NC	0644
119	Upstairs Classroom BR	HS	BS	NC	0647
120	Upstairs Classroom	Slop Sink (Do Not Sample)	OT	NC	-
121	Upstairs Classroom	HS	CR	NC	0647
122	D101A Machine Shop Tri-Sink	Sink-L	CR	NC	0649
123	D101A Machine Shop Tri-Sink	Sink-C	CR	NC	0649
124	D101A Machine Shop Tri-Sink	Sink-R	CR	NC	0649
125	D101A Machine Shop Water Fountain	B	DF	C	0649
126	D101A Machine Shop Locker Room	HS	BS	NC	0650
127	Water Fountain (By Elect. Room)	Drinking Fountain (DF)	DF	C	0650
128	B-104 Practical Nursing Utility Room	HS	CR	NC	0654
129	B-104 Hall Sink	HS (REMOVED)	OT	NC	NO OUTLET
130	B-104 Hall Fountain	DF	DF	C	NOT WORKING
131	B-104 Tri-Sink	Sink-L	CR	NC	0656
132	B-104 Tri-Sink	Sink-C	CR	NC	0656
133	B-104 Tri-Sink	Sink-R	CR	NC	0656
134	B-104 BR-Left	HS	BS	NC	0657 DRINKING
135	B-104 BR-Right	HS	BS	NC	0657
136	B-102 Graphic Design Men's BR	HS	BS	NC	0658
137	B-102 Graphic Design Women's BR	HS	BS	NC	0659
138	B-101 Network Tech. Dual Sink	HS-L	CR	NC	0659



KCI Technologies, Inc. Chain of Custody

KCI Technologies, Inc. 936 Ridgebrook Rd., Baltimore, MD 21152 (410) 316-7800 John.Adams@kci.com

AACPS Drinking Water Lead Survey

Center of Applied Technology North CATN (9513)

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bib, etc.)	Outlet Key Codes	Consumption C or NC	Sample Time
139	B-101 Network Tech. Dual Sink	HS-R	CR	NC	0701
140	B-101 Network Tech. Water Fountain	B	DF	C	0701
141	B-101 Network Tech. Men's BR	HS	BS	NC	0702
142	B-101 Network Tech. Women's BR	HS	BS	NC	0702
143	B-103 Computer Network Tech. Women's BR	HS	BS	NC	0705
144	B-103 Computer Network Tech. Men's BR	HS	BS	NC	0705
145	B-103 Computer Network Tech. Water Fountain	B	DF	C	0705
146	B-103 Computer Network Tech. Dual Sink	Sink-L	CR	NC	0706
147	B-103 Computer Network Tech. Dual Sink	Sink-R	CR	NC	0706
148	B-105 Drafting Dual Sink	Sink-L	CR	NC	0708
149	B-105 Drafting Dual Sink	Sink-R	CR	NC	0708
150	B-105 Drafting Water Fountain	B	DF	C	0709
151	B-105 Drafting Men's BR	HS <i>NOT ONLY</i>	BS	NC	0714
152	B-105 Drafting Dual Women's BR	HS	BS	NC	0714
153	B-107 Graphic Arts Women's BR	HS	BS	NC	0716
154	B-107 Graphic Arts Men's BR	HS	BS	NC	0716
155	B-107 Graphic Arts Water Fountain	B	DF	C	0717
156	B-107 Graphic Arts Dual Sink	Sink-L	CR	NC	0717
157	B-107 Graphic Arts Dual Sink	Sink-R	CR	NC	0717
158	B-109 Cosmetology	Sprayer (Do Not Sample)	OT	NC	-
159	B-109 Cosmetology	Sprayer-L (Do Not Sample)	OT	NC	-
160	B-109 Cosmetology	Sprayer-LC (Do Not Sample)	OT	NC	-
161	B-109 Cosmetology	Sprayer-RC (Do Not Sample)	OT	NC	-
162	B-109 Cosmetology	Sprayer-R (Do Not Sample)	OT	NC	-



KCI Technologies, Inc. Chain of Custody

KCI Technologies, Inc. 936 Ridgebrook Rd., Baltimore, MD 21152 (410) 316-7800 John.Adams@kci.com

AACPS Drinking Water Lead Survey

Center of Applied Technology North CATN (9513)

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bib, etc.)	Outlet Key Codes	Consumption C or NC	Sample Time
163	B-109 Cosmetology BR	HS	BS	NC	0722
164	B-109 Cosmetology Women's Dressing Room	HS-L	OT	NC	0722
165	B-109 Cosmetology Women's Dressing Room	HS-R	OT	NC	0722
166	B-109 Cosmetology Classroom	Sprayer (Do Not Sample)	OT	NC	-
167	Counseling Office BR	HS	BS	NC	0723
168	Media Work Room	HS	OT	NC	0725
169	Hall Fountain (by Faculty Room)	DF	DF	C	0727
170	Faculty Men's BR (By B-168 Lounge)	HS	BS	NC	0728
171	Faculty Women's BR (By B-168 Lounge)	HS	BS	NC	0729
172	Hall Fountain (By B-168 Lounge)	DF	DF	C	0731
173	Green House Women's BR	HS-L	BS	NC	0743
174	Green House Women's BR	HS-R	BS	NC	0743
175	Green House Men's Locker Room BR	HS	BS	NC	0744 <i>Dr. Adams</i>
176	E104-Tri-Sink	Sink-L	CR	NC	0744
177	E104-Tri-Sink	Sink-C	CR	NC	0745
178	E104-Tri-Sink	Sink-R	CR	NC	0745
179	E104-Water Fountain	B	DF	C	0745
180	E102-Equipment Maintenance Water Fountain	B	DF	C	0747
181	E102-Equipment Maintenance Tri-Sink	Sink-L	CR	NC	0747
182	E102-Equipment Maintenance Tri-Sink	Sink-C	CR	NC	0747
183	E102-Equipment Maintenance Tri-Sink	Sink-R	CR	NC	0747
184	Training Facilities Men's BR	HS	BS	NC	0749
185	Training Facilities Women's BR	HS	BS	NC	0749



KCI Technologies, Inc. Chain of Custody

KCI Technologies, Inc. 936 Ridgebrook Rd., Baltimore, MD 21152 (410) 316-7800 John.Adams@kci.com

AACPS Drinking Water Lead Survey

Center of Applied Technology North CATN (9513)

Sample #	Room #	Fixture Type (Sink, bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bib, etc.)	Outlet Key Codes	Consumption C or NC	Sample Time
184	DIESEL MECHANIC SHOP	WATER FOUNTAIN BETWEEN BR'S	DF	C	0543
187	HALLWAY NEAR GRAPHIC LOUNGE ARTS	WATER FOUNTAIN	DF	C	0628