

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **Crofton Meadows Elementary School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On November 20, 2018, **one hundred sixteen (116)** lead water samples were collected from **Crofton Meadows Elementary School**. Of these lead water samples, one (1) had a level of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead result from the sample(s) collected at Crofton Meadows Elementary School were as follows:

Sample Number 000008-Kitchen (left of tri-sink) Hand Sink: 29.8 ppb (non-consumable).

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

1. One (1) non-consumable water source consisting of a hand sink will be marked with signage indicating for "Hand Washing Only" and retested.

NEXT STEPS

1. One (1) non-consumable water source will be replaced and retested in accordance with the regulations



AACPS - Operations Division
9034 Ft. Smallwood Road

Monday, February 4, 2019

Pasadena, MD 21122

Attention: Chris Williams; Brian Wells

Certificate of Analysis
FINAL

Report for Lab No: 40080.

Crofton Meadows ES (3362)

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on November 20, 2018.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40080	000001	Health Room Bathroom (BR) Hand Sink (HS) [BS--NC]	11/20/2018 04:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 16:39 BJ	
40080	000002	Women's BR-Office HS [BS--NC]	11/20/2018 04:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 16:52 BJ	
40080	000003	Men's BR-Office HS [BS--NC]	11/20/2018 04:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 16:54 BJ	
40080	000004	Fountain (outside Café) HS [DF--C]	11/20/2018 04:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 16:56 BJ	
40080	000005	134 (stage)-BR HS [BS--NC]	11/20/2018 04:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 16:59 BJ	
40080	000006	Kitchen (outside 153 Office) HS [KS--NC]	11/20/2018 04:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	



MARTEL NO. 40080 000006 CLIENT SAMPLE IDENTIFICATION Kitchen (outside 153 Office) HS [KS--NC] Sample Date/Time 11/20/2018 04:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:01 BJ

MARTEL NO. 40080 000007 CLIENT SAMPLE IDENTIFICATION Kitchen BR HS [BS--NC] Sample Date/Time 11/20/2018 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:04 BJ

MARTEL NO. 40080 000008 CLIENT SAMPLE IDENTIFICATION Kitchen (left of tri-sink) HS [KS--NC] Sample Date/Time 11/20/2018 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	29.8	ug/l*	EPA .200.8	2	01/23/2019 17:06 BJ

MARTEL NO. 40080 000009 CLIENT SAMPLE IDENTIFICATION Kitchen Tri-sink Sink-Left (L) [KS--C] Sample Date/Time 11/20/2018 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.64	ug/l	EPA .200.8	2	01/23/2019 17:09 BJ

MARTEL NO. 40080 000010 CLIENT SAMPLE IDENTIFICATION Kitchen Tri-Sink Sink-Right (R.) [KS--C] Sample Date/Time 11/20/2018 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:11 BJ

MARTEL NO. 40080 000011 CLIENT SAMPLE IDENTIFICATION Gym Office-BR HS [BS--NC] Sample Date/Time 11/20/2018 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:21 BJ

MARTEL NO. 40080 000012 CLIENT SAMPLE IDENTIFICATION Gym-Boys BR HS [BS--NC] Sample Date/Time 11/20/2018 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:27 BJ

MARTEL NO. 40080 000013 CLIENT SAMPLE IDENTIFICATION Gym-Girls BR HS [BS--NC] Sample Date/Time 11/20/2018 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:29 BJ



MARTEL NO. 40080 000014 Music HS [OT--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:32 BJ

MARTEL NO. 40080 000015 Teachers Lounge HS [TL--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:34 BJ

MARTEL NO. 40080 000016 Teachers Lounge Bottle Fill [OT--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA .200.8	2	/ /

MARTEL NO. 40080 000017 A01 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:37 BJ

MARTEL NO. 40080 000018 A01 Bubbler (B) [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:39 BJ

MARTEL NO. 40080 000019 A01-Girls BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:41 BJ

MARTEL NO. 40080 000020 A02-Boys BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:44 BJ

MARTEL NO. 40080 000021 A02 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:52 BJ



MARTEL NO. 40080 000022 A02 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 17:59 BJ

MARTEL NO. 40080 000023 B02 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:01 BJ

MARTEL NO. 40080 000024 B02 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:04 BJ

MARTEL NO. 40080 000025 B02-Boys BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:06 BJ

MARTEL NO. 40080 000026 B01-Girls BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:09 BJ

MARTEL NO. 40080 000027 B01 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:11 BJ

MARTEL NO. 40080 000028 B01 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:14 BJ

MARTEL NO. 40080 000029 C01 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.26	ug/l	EPA .200.8	2	01/23/2019 18:16 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40080	000030	C01 B [DF--C]	11/20/2018 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:19 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40080	000031	C01-Girls BR HS [BS--NC]	11/20/2018 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:28 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40080	000032	C02-Boys BR HS [BS--NC]	11/20/2018 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:33 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40080	000033	C02 HS [CR--NC]	11/20/2018 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:36 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40080	000034	C02 B [DF--C]	11/20/2018 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:38 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40080	000035	D02 HS [CR--NC]	11/20/2018 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:41 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40080	000036	D02 B [DF--C]	11/20/2018 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:43 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40080	000037	D02-Boys BR HS [BS--NC]	11/20/2018 05:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:46 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000038	D01-Girls BR HS [BS--NC]			11/20/2018 05:15
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:48 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000039	D01 HS [CR--NC]			11/20/2018 05:15
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:51 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000040	D01 B [DF--C]			11/20/2018 05:15
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 18:53 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000041	E01 HS [CR--NC]			11/20/2018 05:15
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 19:01 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000042	E01 B [DF--C]			11/20/2018 05:15
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 19:08 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000043	E01-Girls BR HS [BS--NC]			11/20/2018 05:15
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 19:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000044	E02-Boys BR HS [BS--NC]			11/20/2018 05:15
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 19:13 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000045	E02 HS [CR--NC]			11/20/2018 05:15
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 19:16 BJ



MARTEL NO. 40080 000046 E02 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 19:18 BJ

MARTEL NO. 40080 000047 S02 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.95	ug/l	EPA .200.8	2	01/23/2019 19:20 BJ

MARTEL NO. 40080 000048 S02 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.94	ug/l	EPA .200.8	2	01/23/2019 19:23 BJ

MARTEL NO. 40080 000049 S02-Boys BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 19:25 BJ

MARTEL NO. 40080 000050 S01-Girls BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 19:28 BJ

MARTEL NO. 40080 000051 S01 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 19:38 BJ

MARTEL NO. 40080 000052 S01 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 19:43 BJ

MARTEL NO. 40080 000053 Science HS (next to glassware) [OT--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.8	ug/l	EPA .200.8	2	01/23/2019 19:45 BJ



MARTEL NO. 40080 000054 CLIENT SAMPLE IDENTIFICATION: Science-Tri-Sink HS (next to glassware) [OT--NC] Sample Date/Time: 11/20/2018 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.3	ug/l	EPA .200.8	2	01/23/2019 19:48 BJ

MARTEL NO. 40080 000055 CLIENT SAMPLE IDENTIFICATION: Science-Tri-Sink HS (next to black counter) [OT--] Sample Date/Time: 11/20/2018 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	18.3	ug/l	EPA .200.8	2	01/23/2019 19:50 BJ

MARTEL NO. 40080 000056 CLIENT SAMPLE IDENTIFICATION: Science-Tri-Sink HS (closest to emergency shower) Sample Date/Time: 11/20/2018 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.6	ug/l	EPA .200.8	2	01/23/2019 19:53 BJ

MARTEL NO. 40080 000057 CLIENT SAMPLE IDENTIFICATION: Science Tri-Sink (closest to window) HS (closest to) Sample Date/Time: 11/20/2018 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.77	ug/l	EPA .200.8	2	01/23/2019 19:55 BJ

MARTEL NO. 40080 000058 CLIENT SAMPLE IDENTIFICATION: Science Tri-Sink (closest to window) HS (corner) Sample Date/Time: 11/20/2018 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.01	ug/l	EPA .200.8	2	01/23/2019 19:58 BJ

MARTEL NO. 40080 000059 CLIENT SAMPLE IDENTIFICATION: Science Tri-Sink (closest to window) HS (window) Sample Date/Time: 11/20/2018 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.7	ug/l	EPA .200.8	2	01/23/2019 20:00 BJ

MARTEL NO. 40080 000060 CLIENT SAMPLE IDENTIFICATION: Science Work Room HS [OT--NC] Sample Date/Time: 11/20/2018 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.78	ug/l	EPA .200.8	2	01/23/2019 20:02 BJ

MARTEL NO. 40080 000061 CLIENT SAMPLE IDENTIFICATION: R03-Boys BR HS [BS--NC] Sample Date/Time: 11/20/2018 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:10 BJ



MARTEL NO. 40080 000062 R03-Girls BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:18 BJ

MARTEL NO. 40080 000063 R03 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:20 BJ

MARTEL NO. 40080 000064 R03 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:23 BJ

MARTEL NO. 40080 000065 Art HS [OT--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.1	ug/l	EPA .200.8	2	01/23/2019 20:25 BJ

MARTEL NO. 40080 000066 Art-Girls BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:28 BJ

MARTEL NO. 40080 000067 Art-Boys BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:30 BJ

MARTEL NO. 40080 000068 Art-Tri-Sink HS [OT--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:33 BJ

MARTEL NO. 40080 000069 Art-Tri-Sink HS (closest to Boys BR) [OT--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/20/2018 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:35 BJ



MARTEL NO. 40080 000070 CLIENT SAMPLE IDENTIFICATION Art-Tri-Sink HS (closest to window) [OT--NC] Sample Date/Time 11/20/2018 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:38 BJ

MARTEL NO. 40080 000071 CLIENT SAMPLE IDENTIFICATION K101 HS [CR--NC] Sample Date/Time 11/20/2018 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:47 BJ

MARTEL NO. 40080 000072 CLIENT SAMPLE IDENTIFICATION K101 B [DF--C] Sample Date/Time 11/20/2018 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:52 BJ

MARTEL NO. 40080 000073 CLIENT SAMPLE IDENTIFICATION K101-BR HS [BS--NC] Sample Date/Time 11/20/2018 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:55 BJ

MARTEL NO. 40080 000074 CLIENT SAMPLE IDENTIFICATION K102 HS [CR--NC] Sample Date/Time 11/20/2018 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 20:57 BJ

MARTEL NO. 40080 000075 CLIENT SAMPLE IDENTIFICATION K102 B [DF--C] Sample Date/Time 11/20/2018 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:00 BJ

MARTEL NO. 40080 000076 CLIENT SAMPLE IDENTIFICATION K102-BR HS [BS--NC] Sample Date/Time 11/20/2018 05:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:02 BJ

MARTEL NO. 40080 000077 CLIENT SAMPLE IDENTIFICATION K103 HS [CR--NC] Sample Date/Time 11/20/2018 05:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:05 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000078	K103 B	[DF--C]		11/20/2018 05:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:07 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000079	K103-BR HS	[BS--NC]		11/20/2018 05:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:10 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000080	K104 HS	[CR--NC]		11/20/2018 05:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:12 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000081	K104 B	[DF--C]		11/20/2018 05:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:20 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000082	K104-BR HS	[BS--NC]		11/20/2018 05:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:27 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000083	K105 HS	[CR--NC]		11/20/2018 05:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:30 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000084	K105 B	[DF--C]		11/20/2018 05:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:32 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40080	000085	K105-BR HS	[BS--NC]		11/20/2018 05:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:35 BJ



MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION K106 HS [CR--NC] Sample Date/Time 11/20/2018 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:37 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION K106 B [DF--C] Sample Date/Time 11/20/2018 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:40 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION K106-BR HS [BS--NC] Sample Date/Time 11/20/2018 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:42 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION J02 HS [CR--NC] Sample Date/Time 11/20/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:45 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION J02 B [DF--C] Sample Date/Time 11/20/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:47 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION J02-Boys BR HS [BS--NC] Sample Date/Time 11/20/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 21:57 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION J01-Girls BR HS [BS--NC] Sample Date/Time 11/20/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:02 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION J01 HS [CR--NC] Sample Date/Time 11/20/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.11	ug/l	EPA .200.8	2	01/23/2019 22:05 BJ



MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000094 J01 B [DF--C] 11/20/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.06	ug/l	EPA .200.8	2	01/23/2019 22:07 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000095 H01 HS [CR--NC] 11/20/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:10 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000096 H01 B [DF--C] 11/20/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:12 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000097 H01-Girls BR HS [BS--NC] 11/20/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:15 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000098 H02-Boys BR HS [BS--NC] 11/20/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:17 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000099 H02 HS [CR--NC] 11/20/2018 06:00


Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:20 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000100 H02 B [DF--C] 11/20/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:22 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000101 G02 HS [CR--NC] 11/20/2018 06:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:30 BJ



MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION G02 B [DF--C] Sample Date/Time 11/20/2018 06:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:37 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION G02-Boys BR HS [BS--NC] Sample Date/Time 11/20/2018 06:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:40 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION G01-Girls BR HS [BS--NC] Sample Date/Time 11/20/2018 06:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:42 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION G01 HS [CR--NC] Sample Date/Time 11/20/2018 06:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.6	ug/l	EPA .200.8	2	01/23/2019 22:45 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION G01 B [DF--C] Sample Date/Time 11/20/2018 06:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:47 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION F01 HS [CR--NC] Sample Date/Time 11/20/2018 06:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:50 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION F01 B [DF--C] Sample Date/Time 11/20/2018 06:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:52 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION F01-Girls BR HS [BS--NC] Sample Date/Time 11/20/2018 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:55 BJ



MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000110 F02-Boys BR HS [BS--NC] 11/20/2018 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 22:57 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000111 F02 HS [CR--NC] 11/20/2018 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 23:07 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000112 F02 B [DF--C] 11/20/2018 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 23:12 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000113 K01 HS [CR--NC] 11/20/2018 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 23:15 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000114 K01 Bottle Fill [OT--C] 11/20/2018 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA .200.8	2	/ /

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000115 K01-Boys BR HS-L [BS--NC] 11/20/2018 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 23:17 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000116 K01-Boys BR HS-R [BS--NC] 11/20/2018 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 23:20 BJ

MARTEL NO. 40080 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000117 K01-Girls BR HS-L [BS--NC] 11/20/2018 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/23/2019 23:23 BJ



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
40080	000118	K01-Girls BR HS-R [BS--NC]				11/20/2018 06:18	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	2.03	ug/l	EPA .200.8	2	01/23/2019 23:25 BJ		

Page 16 OF 16

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stdl.frx

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

* results exceeded 20.5 ug/l.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO₃ Analysis: Lead (EPA 200.8)

Start Date/Time: 11/20/18 4:45 End Date/Time: 11/20/18 6:18

Sampler/Relinquished By: [Signature] Received at Martel by [Signature] Date/Time: 11/20/18 19:05

Crofton Meadows ES (3362) Martel No. 40080

2020 Tilghman Dr, Crofton, MD 21114

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM

Sample #	Room #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, etc.)</small>	Outlet Key Code#	Consumption C or NC?	Time/notes	
1	Health Room Bathroom (BR)	Hand Sink (HS)	BS	NC	4:45	
2	Women's BR-Office	HS	BS	NC	↓	
3	Men's BR-Office	HS	BS	NC		
4	Fountain (outside Café)	HS	DF	C		
5	134 (stage)-BR	HS	BS	NC		
6	Kitchen (outside 153 Office)	HS	KS	NC		
7	Kitchen BR	HS	BS	NC		4:50
8	Kitchen (left of tri-sink)	HS	KS	NC		
9	Kitchen Tri-sink	Sink-Left (L)	KS	C		
10	Kitchen Tri-Sink	Sink-Right (R.)	KS	C		
11	Gym Office-BR	HS	BS	NC		
12	Gym-Boys BR	HS	BS	NC		
13	Gym-Girls BR	HS	BS	NC		
14	Music	HS	OT	NC		
15	Teachers Lounge	HS	TL	C		5:00
16	Teachers Lounge	Bottle Fill	OT	C	NW	
17	A01	HS	CR	NC	↓	
18	A01	Bubbler (B)	DF	C		
19	A01-Girls BR	HS	BS	NC		
20	A02-Boys BR	HS	BS	NC		
21	A02	HS	CR	NC		
22	A02	B	DF	C		
23	B02	HS	CR	NC		
24	B02	B	DF	C		
25	B02-Boys BR	HS	BS	NC		5:05









Crofton Meadows ES (3362) Martel No. 40080

2020 Tilghman Dr, Crofton, MD 21114

26	B01-Girls BR	HS	BS	NC	↓
27	B01	HS	CR	NC	
28	B01	B	DF	C	5:10
29	C01	HS	CR	NC	
30	C01	B	DF	C	↓
31	C01-Girls BR	HS	BS	NC	
32	C02-Boys BR	HS	BS	NC	5:15
33	C02	HS	CR	NC	
34	C02	B	DF	C	↓
35	D02	HS	CR	NC	
36	D02	B	DF	C	5:20
37	D02-Boys BR	HS	BS	NC	
38	D01-Girls BR	HS	BS	NC	↓
39	D01	HS	CR	NC	
40	D01	B	DF	C	5:30
41	E01	HS	CR	NC	
42	E01	B	DF	C	↓
43	E01-Girls BR	HS	BS	NC	
44	E02-Boys BR	HS	BS	NC	5:20
45	E02	HS	CR	NC	
46	E02	B	DF	C	↓
47	S02	HS	CR	NC	
48	S02	B	DF	C	5:30
49	S02-Boys BR	HS	BS	NC	
50	S01-Girls BR	HS	BS	NC	↓
51	S01	HS	CR	NC	
52	S01	B	DF	C	5:30
53	Science	HS (next to glassware)	OT	NC	
54	Science-Tri-Sink	HS (next to glassware)	OT	NC	↓
55	Science-Tri-Sink	HS (next to black counter)	OT	NC	
56	Science-Tri-Sink	HS (closest to emergency shower)	OT	NC	5:30
57	Science Tri-Sink (closest to window)	HS (closest to emergency shower)	OT	NC	
58	Science Tri-Sink (closest to window)	HS (corner)	OT	NC	↓
59	Science Tri-Sink (closest to window)	HS (window)	OT	NC	
60	Science Work Room	HS	OT	NC	↓
61	R03-Boys BR	HS	BS	NC	

Crofton Meadows ES (3362) Martel No. 40080

2020 Tilghman Dr, Crofton, MD 21114

62	R03-Girls BR	HS	BS	NC	
63	R03	HS	CR	NC	
64	R03	B	DF	C	
65	Art	HS	OT	NC	S:35
66	Art-Girls BR	HS	BS	NC	
67	Art-Boys BR	HS	BS	NC	
68	Art-Tri-Sink	HS	OT	NC	
69	Art-Tri-Sink	HS (closest to Boys BR)	OT	NC	
70	Art-Tri-Sink	HS (closest to window)	OT	NC	S:40
71	K101	HS	CR	NC	
72	K101	B	DF	C	
73	K101-BR	HS	BS	NC	
74	K102	HS	CR	NC	
75	K102	B	DF	C	S:45
76	K102-BR	HS	BS	NC	
77	K103	HS	CR	NC	
78	K103	B	DF	C	
79	K103-BR	HS	BS	NC	
80	K104	HS	CR	NC	
81	K104	B	DF	C	
82	K104-BR	HS	BS	NC	
83	K105	HS	CR	NC	
84	K105	B	DF	C	
85	K105-BR	HS	BS	NC	
86	K106	HS	CR	NC	
87	K106	B	DF	C	
88	K106-BR	HS	BS	NC	
89	J02	HS	CR	NC	S:55
90	J02	B	DF	C	
91	J02-Boys BR	HS	BS	NC	
92	J01-Girls BR	HS	BS	NC	
93	J01	HS	CR	NC	
94	J01	B	DF	C	
95	H01	HS	CR	NC	6:00
96	H01	B	DF	C	
97	H01-Girls BR	HS	BS	NC	

Crofton Meadows ES (3362) Martel No. 40080

2020 Tilghman Dr, Crofton, MD 21114

98	H02-Boys BR	HS	BS	NC	↓
99	H02	HS	CR	NC	
100	H02	B	DF	C	↓
101	G02	HS	CR	NC	6:05
102	G02	B	DF	C	↓
103	G02-Boys BR	HS	BS	NC	
104	G01-Girls BR	HS	BS	NC	
105	G01	HS	CR	NC	
106	G01	B	DF	C	
107	F01	HS	CR	NC	↓
108	F01	B	DF	C	
109	F01-Girls BR	HS	BS	NC	6:10
110	F02-Boys BR	HS	BS	NC	↓
111	F02	HS	CR	NC	
112	F02	B	DF	C	↓
113	K01	HS	CR	NC	
114	K01	Bottle Fill	OT	C	
115	K01-Boys BR	HS-L	BS	NC	↓
116	K01-Boys BR	HS-R	BS	NC	
117	K01-Girls BR	HS-L	BS	NC	
118	K01-Girls BR	HS-R	BS	NC	

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact Chris Williams, Environmental Issues Program Manager, at 410-360-0138. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.