

# Lead in Drinking Water – Public and Nonpublic Schools

*Updated in response to legislation effective as of June 1, 2021*

## **IMPORTANT NOTICE: ELEVATED LEAD WATER SAMPLE RESULT(S)** **Belvedere Elementary School**

### **ELEVATED LEAD WATER SAMPLE RESULT(S)**

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On October 11, 2023, fifty-two (52) lead water samples were collected from Belvedere Elementary School. Of these lead water samples, one (1) had levels of lead exceeding the State's revised action level of 5 parts per billion (ppb) (*formerly 20 ppb; 5 ppb effective June 1, 2021*) for lead in drinking water in school buildings. The elevated lead results from the sample(s) collected at Belvedere Elementary School were as follows:

6.32 (ppb) Sample #119 Classroom Room 210 Combination Fountain

### **ACTION LEVEL (AL)**

Effective June 1, 2021, the State's AL for lead in drinking water samples collected from outlets in school buildings has been lowered to 5 ppb. The AL is the concentration of lead which, if exceeded, triggers required remediation of drinking water outlets.

### **HEALTH EFFECTS OF LEAD**

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones, and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### **SOURCES OF HUMAN EXPOSURE TO LEAD**

There are many different sources of human exposure to lead. These sources include lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the workplace and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

### **IMMEDIATE ACTIONS TAKEN**

All consumable outlets exceeding the Action Level were turned off or a "Hand Washing Only", "Do Not Drink" or "Dish Washing Only" sticker was applied.

### **NEXT STEPS**

Sample #119 Classroom Room 210 Combination Fountain will be removed.

### **TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:**

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

*Please note that boiling the water will not reduce lead levels.*

**ADDITIONAL INFORMATION**

For additional information, please contact the Environmental, Health and Safety Office at 443-770-5950. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at [www.epa.gov/lead](http://www.epa.gov/lead). If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



**AACPS - Operations Division**  
9034 Ft. Smallwood Road

Pasadena, MD 21122  
**Attention: Chris Williams; Brian Wells**

Friday, February 2, 2024

***Certificate of Analysis***  
**FINAL**

**Project Information:**

Report for Lab No: 70016.

School: Belvedere ES

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 21B21062901660

Sampling by Martel personnel on October 11, 2023.

**References and Important Notes:**

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date.  
40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

\* results exceeded 5.5 ug/l.

**Notices:**

Chain of Custody Form(s) are attached and are an integral part of this report.  
This report will be retained for at least five years and will be disposed of without notice.  
Measurement uncertainty for each listed test is available upon request.  
The results presented herein relate only to the samples or items tested.  
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO. 70016	1	CLIENT SAMPLE IDENTIFICATION Nurses Office Health Room [NO--C]	Sample Date/Time 10/11/2023 05:45
---------------------	---	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/26/2024 11:46 EK

MARTEL NO. 70016	2	CLIENT SAMPLE IDENTIFICATION Nurses Office Health Room Bathroom (BR) [BS--C]	Sample Date/Time 10/11/2023 05:47
---------------------	---	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/26/2024 11:58 EK

MARTEL NO. 70016	3	CLIENT SAMPLE IDENTIFICATION Other Main Office Work Room [OT--C]	Sample Date/Time 10/11/2023 05:48
---------------------	---	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/26/2024 12:01 EK

MARTEL NO. 70016	4	CLIENT SAMPLE IDENTIFICATION Lounge Conference Room [OT--C]	Sample Date/Time 10/11/2023 05:49
---------------------	---	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/26/2024 12:03 EK

MARTEL NO. 70016	9	CLIENT SAMPLE IDENTIFICATION Hallway Hall Fountain (next to 107) [DF--C]	Sample Date/Time 10/11/2023 05:51
---------------------	---	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/26/2024 12:06 EK

MARTEL NO. 70016	11	CLIENT SAMPLE IDENTIFICATION Classroom Room 109 Combination Fountain -Left [CF--C]	Sample Date/Time 10/11/2023 05:52
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/26/2024 12:08 EK

MARTEL NO. 70016	13	CLIENT SAMPLE IDENTIFICATION Classroom Room 109 Combination Fountain -Left/Center	Sample Date/Time 10/11/2023 05:53
---------------------	----	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/26/2024 12:10 EK

MARTEL NO. 70016	15	CLIENT SAMPLE IDENTIFICATION Classroom Room 109 Combination Fountain -Right/Center	Sample Date/Time 10/11/2023 05:54
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/26/2024 12:13 EK



MARTEL NO. 70016	17	CLIENT SAMPLE IDENTIFICATION Classroom Room 109 Combination Fountain -Right [CF--C]	Sample Date/Time 10/11/2023 05:55
---------------------	----	--	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:15 EK

MARTEL NO. 70016	22	CLIENT SAMPLE IDENTIFICATION Classroom Room 113 Combination Fountain -Left [CF--C]	Sample Date/Time 10/11/2023 05:57
---------------------	----	---	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:18 EK

MARTEL NO. 70016	24	CLIENT SAMPLE IDENTIFICATION Classroom Room 113 Combination Fountain -Left/Center	Sample Date/Time 10/11/2023 05:58
---------------------	----	--	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:28 EK

MARTEL NO. 70016	26	CLIENT SAMPLE IDENTIFICATION Classroom Room 113 Combination Fountain -Right/Center	Sample Date/Time 10/11/2023 06:00
---------------------	----	---	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:33 EK

MARTEL NO. 70016	28	CLIENT SAMPLE IDENTIFICATION Classroom Room 113 Combination Fountain -Right [CF--C]	Sample Date/Time 10/11/2023 06:02
---------------------	----	--	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:35 EK

MARTEL NO. 70016	33	CLIENT SAMPLE IDENTIFICATION Classroom Room 115 [CF--C]	Sample Date/Time 10/11/2023 06:05
---------------------	----	--	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:38 EK

MARTEL NO. 70016	34	CLIENT SAMPLE IDENTIFICATION Hallway Hall Fountain (next to 117 Art) [DF--C]	Sample Date/Time 10/11/2023 06:06
---------------------	----	---	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:40 EK

MARTEL NO. 70016	38	CLIENT SAMPLE IDENTIFICATION Classroom Room 112 [CF--C]	Sample Date/Time 10/11/2023 06:07
---------------------	----	--	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:42 EK



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	41	Classroom Room 110 [CF--C]					10/11/2023 06:08

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:45 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	44	Classroom Room 108 [CF--C]					10/11/2023 06:09

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:47 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	48	Classroom Room 106 [CF--C]					10/11/2023 06:10

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:50 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	51	Classroom Room 104 [CF--C]					10/11/2023 06:13

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 12:52 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	54	Classroom Room 102 [CF--C]					10/11/2023 06:15

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:00 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	57	Classroom Room 100 [CF--C]					10/11/2023 06:19

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:07 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	59	Lounge Faculty Lounge [TL--C]					10/11/2023 06:20

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:09 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	61	Classroom Instrumental Music [CF--C]					10/11/2023 06:23

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		4.11	ug/l	EPA .200.8	2	01/26/2024 13:12 EK



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	64	Classroom General Music [CF--C]					10/11/2023 06:25

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:14 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	67	Kitchen Tri Sink- L [KS--C]					10/11/2023 06:27

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:17 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	68	Kitchen Tri Sink- R [KS--C]					10/11/2023 06:28

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:19 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	68A	Kitchen Single Deep Sink [KS--C]					10/11/2023 06:29

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		2.36	ug/l	EPA .200.8	2	01/26/2024 13:22 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	70	Cafeteria Café Fountain [DF--C]					10/11/2023 06:30

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:24 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	72	Gymnasium Gym Fountain -Left [DF--C]					10/11/2023 06:31

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:26 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	73	Gymnasium Gym Fountain -Right [DF--C]					10/11/2023 06:32

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:36 EK

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
70016	76	Hallway Fountain (outside café) -Left [DF--C]					10/11/2023 06:33

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:41 EK



MARTEL NO. 70016	77	CLIENT SAMPLE IDENTIFICATION Hallway Fountain (outside café) -Left [DF--C]				Sample Date/Time 10/11/2023 06:34
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:43 EK
MARTEL NO. 70016	82	CLIENT SAMPLE IDENTIFICATION Office Media Office [OT--C]				Sample Date/Time 10/11/2023 06:35
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:46 EK
MARTEL NO. 70016	83	CLIENT SAMPLE IDENTIFICATION Hallway Hall Fountain (outside Health) [DF--C]				Sample Date/Time 10/11/2023 06:37
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:48 EK
MARTEL NO. 70016	93	CLIENT SAMPLE IDENTIFICATION Classroom Room 205 [CF--C]				Sample Date/Time 10/11/2023 06:39
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:51 EK
MARTEL NO. 70016	96	CLIENT SAMPLE IDENTIFICATION Classroom Room 207 [CF--C]				Sample Date/Time 10/11/2023 06:40
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:53 EK
MARTEL NO. 70016	99	CLIENT SAMPLE IDENTIFICATION Classroom Room 209 [CF--C]				Sample Date/Time 10/11/2023 06:42
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:55 EK
MARTEL NO. 70016	101	CLIENT SAMPLE IDENTIFICATION Hallway Hall Fountain (next to storage 18) [DF--C]				Sample Date/Time 10/11/2023 06:45
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 13:58 EK
MARTEL NO. 70016	103	CLIENT SAMPLE IDENTIFICATION Classroom Room 211 [CF--C]				Sample Date/Time 10/11/2023 06:48
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:00 EK





MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	106	Classroom Room 213 [CF--C]				10/11/2023 06:50	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:07 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	109	Classroom Room 215 [CF--C]				10/11/2023 06:52	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:15 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	112	Classroom Room 217 [CF--C]				10/11/2023 06:55	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:17 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	114	Hallway Hall Fountain (next to custodial 3) [DF--C]				10/11/2023 06:57	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:20 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	116	Classroom Room 212 [CF--C]				10/11/2023 07:00	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:22 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	119	Classroom Room 210 [CF--C]				10/11/2023 07:02	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		6.32	ug/l*	EPA .200.8	2	01/26/2024 14:25 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	122	Classroom Room 208 [CF--C]				10/11/2023 07:08	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:27 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	126	Classroom Room 206 [CF--C]				10/11/2023 07:10	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:29 EK	



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	129	Classroom Room 204 [CF--C]				10/11/2023 07:12	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:32 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	132	Classroom Room 202 [CF--C]				10/11/2023 07:15	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:34 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	135	Classroom Room 200 [CF--C]				10/11/2023 07:16	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:44 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	67F	Kitchen Tri Sink- L [KS--C]				10/11/2023 07:20	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:49 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	68F	Kitchen Tri Sink- R [KS--C]				10/11/2023 07:23	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:51 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70016	68A	Kitchen Single Deep Sink [KS--C]				10/11/2023 07:24	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/26/2024 14:54 EK	

# MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

## Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Start Date/Time: 10-11-23

End Date/Time: 10-11-23

Sampler/Relinquished By: Joshua Rogers

Received at Martel by Shelby Lewis

Date/Time: 10/11/23 14:10

Belvedere ES

360 Broadwater Rd, Arnold, MD 21012

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE  
SAMPLING BETWEEN THE HOURS OF 5 PM AND 9PM

Floor

Martel NO:

70016

Martel #	Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)	Outlet Key Codes	Fixture Types Key	Consumption C or NC?	Time/notes
1	1	Nurses Office	Health Room	NO	Faucet, Cold	C	1 5:45
2	2	Nurses Office	Health Room Bathroom (BR)	BS	Faucet, Cold	C	1 5:47
3	3	Other	Main Office Work Room	OT	Faucet, Cold	C	1 5:48
4	4	Lounge	Conference Room	OT	Faucet, Cold	C	1 5:49
5	9	Hallway	Hall Fountain (next to 107)	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1 5:51
6	11	Classroom	Room 109 Combination Fountain -Left	CF	Drinking Water Fountain-Bubbler Style	C	1 5:52
7	13	Classroom	Room 109 Combination Fountain -Left/Center	CF	Drinking Water Fountain-Bubbler Style	C	1 5:53
8	15	Classroom	Room 109 Combination Fountain -Right/Center	CF	Drinking Water Fountain-Bubbler Style	C	1 5:54
9	17	Classroom	Room 109 Combination Fountain -Right	CF	Drinking Water Fountain-Bubbler Style	C	1 5:55
10	22	Classroom	Room 113 Combination Fountain -Left	CF	Drinking Water Fountain-Bubbler Style	C	1 5:57
11	24	Classroom	Room 113 Combination Fountain -Left/Center	CF	Drinking Water Fountain-Bubbler Style	C	1 6:00 5:58
12	26	Classroom	Room 113 Combination Fountain -Right/Center	CF	Drinking Water Fountain-Bubbler Style	C	1 6:00
13	28	Classroom	Room 113 Combination Fountain -Right	CF	Drinking Water Fountain-Bubbler Style	C	1 6:02
14	33	Classroom	Room 115	CF	Drinking Water Fountain-Bubbler Style	C	1 6:05
15	34	Hallway	Hall Fountain (next to 117 Art)	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1 6:06
16	38	Classroom	Room 112	CF	Drinking Water Fountain-Bubbler Style	C	1 6:07
17	41	Classroom	Room 110	CF	Drinking Water Fountain-Bubbler Style	C	1 6:08
18	44	Classroom	Room 108	CF	Drinking Water Fountain-Bubbler Style	C	1 6:09
19	48	Classroom	Room 106	CF	Drinking Water Fountain-Bubbler Style	C	1 6:10
20	51	Classroom	Room 104	CF	Drinking Water Fountain-Bubbler Style	C	1 6:13
21	54	Classroom	Room 102	CF	Drinking Water Fountain-Bubbler Style	C	1 6:15
22	57	Classroom	Room 100	CF	Drinking Water Fountain-Bubbler Style	C	1 6:19
23	59	Lounge	Faculty Lounge	TL	Faucet, Cold	C	1 6:20

P09

1 OF 2

Belvedere ES

360 Broadwater Rd, Arnold, MD 21012

Hand Sink

24	61	Classroom	Instrumental Music	CF	Drinking Water Fountain-Bubbler Style	C	1	6:23
25	64	Classroom	General Music	CF	Drinking Water Fountain-Bubbler Style	C	1	6:25
26	67	Kitchen	Tri Sink- L	KS	Faucet, Cold	C	1	6:27
27	68	Kitchen	Tri Sink- R	KS	Faucet, Cold	C	1	6:28
28	68A	Kitchen	Single Deep Sink	KS	Faucet, Cold	C	1	6:29
29	70	Cafeteria	Café Fountain	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1	6:30
30	72	Gymnasium	Gym Fountain -Left	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1	6:31
31	73	Gymnasium	Gym Fountain -Right	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1	6:32
32	76	Hallway	Fountain (outside café) -Left	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1	6:33
33	77	Hallway	Fountain (outside café) -Left	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1	6:34
34	82	Office	Media Office	OT	Faucet, Cold	C	1	6:35
35	83	Hallway	Hall Fountain (outside Health)	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1	6:37
36	93	Classroom	Room 205	CF	Drinking Water Fountain-Bubbler Style	C	2	6:39
37	96	Classroom	Room 207	CF	Drinking Water Fountain-Bubbler Style	C	2	6:40
38	99	Classroom	Room 209	CF	Drinking Water Fountain-Bubbler Style	C	2	6:42
39	101	Hallway	Hall Fountain (next to storage 18)	DF	Drinking Water Fountain- Cooler/Chiller Style	C	2	6:45
40	103	Classroom	Room 211	CF	Drinking Water Fountain-Bubbler Style	C	2	6:48
41	106	Classroom	Room 213	CF	Drinking Water Fountain-Bubbler Style	C	2	6:50
42	109	Classroom	Room 215	CF	Drinking Water Fountain-Bubbler Style	C	2	6:52
43	112	Classroom	Room 217	CF	Drinking Water Fountain-Bubbler Style	C	2	6:55
44	114	Hallway	Hall Fountain (next to custodial 3)	DF	Drinking Water Fountain- Cooler/Chiller Style	C	2	6:57
45	116	Classroom	Room 212	CF	Drinking Water Fountain-Bubbler Style	C	2	7:00
46	119	Classroom	Room 210	CF	Drinking Water Fountain-Bubbler Style	C	2	7:02
47	122	Classroom	Room 208	CF	Drinking Water Fountain-Bubbler Style	C	2	7:08
48	126	Classroom	Room 206	CF	Drinking Water Fountain-Bubbler Style	C	2	7:10
49	129	Classroom	Room 204	CF	Drinking Water Fountain-Bubbler Style	C	2	7:12
50	132	Classroom	Room 202	CF	Drinking Water Fountain-Bubbler Style	C	2	7:15
51	135	Classroom	Room 200	CF	Drinking Water Fountain-Bubbler Style	C	2	7:16
52	67F	Kitchen	Tri Sink- L	KS	Faucet, Cold	C	1	7:20 FLUSH
53	68F	Kitchen	Tri Sink- R	KS	Faucet, Cold	C	1	7:23 FLUSH
54	68AF	Kitchen	Single Deep Sink	KS	Faucet, Cold	C	1	7:24 FLUSH