

# Lead in Drinking Water – Public and Nonpublic Schools

*Updated in response to legislation effective as of June 1, 2021*

## **IMPORTANT NOTICE: ELEVATED LEAD WATER SAMPLE RESULT(S)**

### **Cape St. Claire Elementary School**

#### **ELEVATED LEAD WATER SAMPLE RESULT(S)**

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On October 10, 2023, forty (40) lead water samples were collected from Cape St. Clair Elementary School. Of these lead water samples, zero (0) had levels of lead exceeding the State's revised action level of 5 parts per billion (ppb) (*formerly 20 ppb; 5 ppb effective June 1, 2021*) for lead in drinking water in school buildings.

#### **ACTION LEVEL (AL)**

Effective June 1, 2021, the State's AL for lead in drinking water samples collected from outlets in school buildings has been lowered to 5 ppb. The AL is the concentration of lead which, if exceeded, triggers required remediation of drinking water outlets.

#### **HEALTH EFFECTS OF LEAD**

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones, and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

#### **SOURCES OF HUMAN EXPOSURE TO LEAD**

There are many different sources of human exposure to lead. These sources include lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the workplace and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

#### **IMMEDIATE ACTIONS TAKEN**

No action was needed.

#### **NEXT STEPS**

N/A

#### **TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:**

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

*Please note that boiling the water will not reduce lead levels.*

**ADDITIONAL INFORMATION**

For additional information, please contact the Environmental, Health and Safety Office at 443-770-5950. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at [www.epa.gov/lead](http://www.epa.gov/lead). If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

## AACPS - Operations Division

9034 Ft. Smallwood Road

Pasadena, MD 21122

Attention: Chris Williams; Brian Wells

Friday, February 2, 2024

## Certificate of Analysis

FINAL

### Project Information:

Report for Lab No: 70015.

School: Cape St. Claire ES

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 21B21062901660

Sampling by Martel personnel on October 10, 2023.

### References and Important Notes:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date.  
40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

### Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.  
This report will be retained for at least five years and will be disposed of without notice.  
Measurement uncertainty for each listed test is available upon request.  
The results presented herein relate only to the samples or items tested.  
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO. 70015 1 CLIENT SAMPLE IDENTIFICATION Nurses Office Health Room [NO--C] Sample Date/Time 10/10/2023 06:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/29/2024 21:05 EK

MARTEL NO. 70015 2 CLIENT SAMPLE IDENTIFICATION Nurses Office Health Room Bathroom (BR) [BS--C] Sample Date/Time 10/10/2023 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/29/2024 21:12 EK

MARTEL NO. 70015 4 CLIENT SAMPLE IDENTIFICATION Lounge Admin Work [OT--C] Sample Date/Time 10/10/2023 06:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/29/2024 21:20 EK

MARTEL NO. 70015 6 CLIENT SAMPLE IDENTIFICATION Classroom Volunteer Room [OT--C] Sample Date/Time 10/10/2023 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.42	ug/l	EPA .200.8	2	01/29/2024 21:22 EK

MARTEL NO. 70015 7 CLIENT SAMPLE IDENTIFICATION Cafeteria Fountain -Left [DF--C] Sample Date/Time 10/10/2023 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/29/2024 21:24 EK

MARTEL NO. 70015 8 CLIENT SAMPLE IDENTIFICATION Cafeteria Fountain -Right [DF--C] Sample Date/Time 10/10/2023 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/29/2024 21:27 EK

MARTEL NO. 70015 10 CLIENT SAMPLE IDENTIFICATION Kitchen Tri Sink -Left [KS--C] Sample Date/Time 10/10/2023 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/29/2024 21:29 EK

MARTEL NO. 70015 11 CLIENT SAMPLE IDENTIFICATION Kitchen Tri Sink -Center [KS--C] Sample Date/Time 10/10/2023 05:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA .200.8	2	/ /



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	12	Kitchen Tri Sink -Right [KS--C]				10/10/2023 05:00	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 21:32 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	13	Kitchen Dual Sink [KS--C]				10/10/2023 05:27	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 21:34 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	15	Gymnasium Fountain [DF--C]				10/10/2023 06:27	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 21:37 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	19	Hallway Hall Fountain (outside Café) [DF--C]				10/10/2023 05:36	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 21:46 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	27	Hallway Hall Fountain (across from 119) [DF--C]				10/10/2023 05:00	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		n/a		EPA .200.8	2	/ /	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	36	Classroom Room 121 [CF--C]				10/10/2023 05:39	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		2.04	ug/l	EPA .200.8	2	01/29/2024 21:51 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	38	Classroom Room 116 [CF--C]				10/10/2023 05:40	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 21:54 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	40	Classroom Room 123 [CF--C]				10/10/2023 05:41	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 21:56 EK	



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	42	Classroom Room 118 [CF--C]				10/10/2023 05:42	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 21:59 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	44	Classroom Room 125 [CF--C]				10/10/2023 05:43	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 22:01 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	46	Classroom Room 120 [CF--C]				10/10/2023 05:00	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		n/a		EPA .200.8	2	/ /	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	50	Classroom Room 122 [CF--C]				10/10/2023 05:47	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 22:04 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	52	Classroom Science Lab [CF--C]				10/10/2023 05:48	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		2.20	ug/l	EPA .200.8	2	01/29/2024 22:06 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	56	Classroom Room 124 [CF--C]				10/10/2023 05:49	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 22:13 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	57	Classroom Special ED #1 [SE--C]				10/10/2023 05:00	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		n/a		EPA .200.8	2	/ /	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	60	Classroom Art Room [CF--C]				10/10/2023 05:52	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		2.98	ug/l	EPA .200.8	2	01/29/2024 22:21 EK	



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	64	Classroom Choral Music Room [CF--C]				10/10/2023 05:53	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 22:23 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	69	Classroom Room 114 [CF--C]				10/10/2023 05:56	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 22:26 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	72	Classroom Room 117 [CF--C]				10/10/2023 05:57	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 22:28 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	75	Classroom Room 112 [CF--C]				10/10/2023 05:58	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 22:31 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	78	Classroom Room 115 [CF--C]				10/10/2023 05:59	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 22:33 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	81	Classroom Room 110 [CF--C]				10/10/2023 06:00	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		2.19	ug/l	EPA .200.8	2	01/29/2024 22:36 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	83	Classroom Room 113 [CF--C]				10/10/2023 06:01	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		2.17	ug/l	EPA .200.8	2	01/29/2024 22:38 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	85	Classroom Room 108 [CF--C]				10/10/2023 06:00	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		n/a		EPA .200.8	2	/ /	



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015 87		Classroom Room 111 [CF--C]				10/10/2023 06:03	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		3.28	ug/l	EPA .200.8	2	01/29/2024 22:48 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015 89		Classroom Room 106 [CF--C]				10/10/2023 06:06	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 22:53 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015 91		Classroom Room 109 [CF--C]				10/10/2023 06:04	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 22:55 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015 95		Hallway Hall Fountain (across from 109) [DF--C]				10/10/2023 06:00	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		n/a		EPA .200.8	2	/ /	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015 101		Lounge Teachers Room [OT--C]				10/10/2023 06:21	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 22:58 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015 104		Classroom Room 104 [CF--C]				10/10/2023 06:08	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:00 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015 107		Classroom Room 103 [CF--C]				10/10/2023 06:09	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:03 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015 113		Classroom Room 101 [CF--C]				10/10/2023 06:10	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:05 EK	





MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	121	Classroom Room 93 [CF--C]				10/10/2023 06:13	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:08 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	124	Classroom Room 92 [CF--C]				10/10/2023 06:14	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:15 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	127	Classroom Room 91 [CF--C]				10/10/2023 06:15	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:23 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	130	Classroom Room 89 [CF--C]				10/10/2023 06:16	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:25 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	133	Classroom Room 88 [CF--C]				10/10/2023 06:17	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:28 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	136	Classroom Room 90 [CF--C]				10/10/2023 06:18	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:30 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	10F	Kitchen Tri Sink -Left [KS--C]				10/10/2023 06:32	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:33 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	11F	Kitchen Tri Sink -Center [KS--C]				10/10/2023 06:00	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		n/a		EPA .200.8	2	/ /	



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	12F	Kitchen Tri Sink -Right [KS--C]				10/10/2023 06:33	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:35 EK	

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70015	13F	Kitchen Dual Sink [KS--C]				10/10/2023 06:30	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/29/2024 23:37 EK	

# MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

## Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Start Date/Time: 10/10/23 05:25 End Date/Time: 10/10/23 06:30

Sampler/Relinquished By: Shelby Lewis Received at Martel by: Shelby Lewis Date/Time: 10/10/23 07:50

Cape St. Claire ES

931 Blue Ridge Dr, Annapolis, MD 21409

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE  
SAMPLING BETWEEN THE HOURS OF 5 PM AND 9PM

Floor

Martel NO:

70015

Martel #	Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)	Outlet Key Codes	Fixture Types Key	Consumption C or MC?	Time/notes
1	1	Nurses Office	Health Room	NO	Faucet, Cold	C	1 06:24
2	2	Nurses Office	Health Room Bathroom (BR)	BS	Faucet, Cold	C	1 06:25
3	4	Lounge	Admin Work	OT	Faucet, Cold	C	1 06:22
4	6	Classroom	Volunteer Room	OT	Faucet, Cold	C	1 06:20
5	7	Cafeteria	Fountain -Left	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1 05:25
6	8	Cafeteria	Fountain -Right	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1 05:25
7	10	Kitchen	Tri Sink -Left	KS	Faucet, Cold	C	1 05:27
8	11	Kitchen	Tri Sink -Center	KS	Faucet, Cold	C	1 only left right faucets
9	12	Kitchen	Tri Sink -Right	KS	Faucet, Cold	C	1 05:28
10	13	Kitchen	Dual Sink	KS	Faucet, Cold	C	1 05:27
11	15	Gymnasium	Fountain	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1 06:27
12	19	Hallway	Hall Fountain (outside Café)	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1 05:36
13	27	Hallway	Hall Fountain (across from 119)	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1 not enough flow to collect sample
14	36	Classroom	Room 121	CF	Drinking Water Fountain-Bubbler Style	C	1 05:39
15	38	Classroom	Room 116	CF	Drinking Water Fountain-Bubbler Style	C	1 05:40
16	40	Classroom	Room 123	CF	Drinking Water Fountain-Bubbler Style	C	1 05:41
17	42	Classroom	Room 118	CF	Drinking Water Fountain-Bubbler Style	C	1 05:42
18	44	Classroom	Room 125	CF	Drinking Water Fountain-Bubbler Style	C	1 05:43
19	46	Classroom	Room 120	CF	Drinking Water Fountain-Bubbler Style	C	1 no flow
20	50	Classroom	Room 122	CF	Drinking Water Fountain-Bubbler Style	C	1 05:47
21	52	Classroom	Science Lab	CF	Drinking Water Fountain-Bubbler Style	C	1 05:48
22	56	Classroom	Room 124	CF	Drinking Water Fountain-Bubbler Style	C	1 05:49
23	57	Classroom	Special ED #1	SE	Faucet, Cold	C	1 does not work

Cape St. Claire ES

931 Blue Ridge Dr, Annapolis, MD 21409

24	60	Classroom	Art Room	CF	Drinking Water Fountain-Bubbler Style	C	1	05:52
25	64	Classroom	Choral Music Room	CF	Drinking Water Fountain-Bubbler Style	C	1	05:53
26	69	Classroom	Room 114	CF	Drinking Water Fountain-Bubbler Style	C	1	05:54
27	72	Classroom	Room 117	CF	Drinking Water Fountain-Bubbler Style	C	1	05:57
28	75	Classroom	Room 112	CF	Drinking Water Fountain-Bubbler Style	C	1	05:58
29	78	Classroom	Room 115	CF	Drinking Water Fountain-Bubbler Style	C	1	05:59
30	81	Classroom	Room 110	CF	Drinking Water Fountain-Bubbler Style	C	1	06:00
31	83	Classroom	Room 113	CF	Drinking Water Fountain-Bubbler Style	C	1	06:01
32	85	Classroom	Room 108	CF	Drinking Water Fountain-Bubbler Style	C	1	no fountain
33	87	Classroom	Room 111	CF	Drinking Water Fountain-Bubbler Style	C	1	06:03
34	89	Classroom	Room 106	CF	Drinking Water Fountain-Bubbler Style	C	1	06:06
35	91	Classroom	Room 109	CF	Drinking Water Fountain-Bubbler Style	C	1	06:04
36	95	Hallway	Hall Fountain (across from 109)	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1	no flow
37	101	Lounge	Teachers Room	OT	Faucet, Cold	C	1	06:21
38	104	Classroom	Room 104	CF	Drinking Water Fountain-Bubbler Style	C	1	06:08
39	107	Classroom	Room 103	CF	Drinking Water Fountain-Bubbler Style	C	1	06:09
40	113	Classroom	Room 101	CF	Drinking Water Fountain-Bubbler Style	C	1	06:10
41	121	Classroom	Room 93	CF	Drinking Water Fountain-Bubbler Style	C	1	06:13
42	124	Classroom	Room 92	CF	Drinking Water Fountain-Bubbler Style	C	1	06:14
43	127	Classroom	Room 91	CF	Drinking Water Fountain-Bubbler Style	C	1	06:15
44	130	Classroom	Room 89	CF	Drinking Water Fountain-Bubbler Style	C	1	06:16
45	133	Classroom	Room 88	CF	Drinking Water Fountain-Bubbler Style	C	1	06:17
46	136	Classroom	Room 90	CF	Drinking Water Fountain-Bubbler Style	C	1	06:18
47	10F	Kitchen	Tri Sink -Left	KS	Faucet, Cold	C	1	FLUSH 06:32
48	11F	Kitchen	Tri Sink -Center	KS	Faucet, Cold	C	1	FLUSH only left/right faucets
49	12F	Kitchen	Tri Sink -Right	KS	Faucet, Cold	C	1	FLUSH 06:33
50	13F	Kitchen	Dual Sink	KS	Faucet, Cold	C	1	FLUSH 06:30